



PROCUREMENT SERVICES

ADDENDUM TO CONTRACT DOCUMENTS

ADDENDUM NO.: 4

SOLICITATION NAME: ITN No. N207381RC – Wastewater & Reverse Osmosis Water Treatment Plant Operations

DATE OF ISSUE: January 21, 2021

The following information shall be included in the ITN documents and is hereby made part of the contract documents in the form of clarification, addition, deletion or revision to the contract specifications.

REMINDER – Proposal are due January 27, 2021 by 2:00 PM.

Proposers' questions/issues and District answers (District answers are italicized):

- Q8. I am reaching you out to follow up about the information needed to finalize the proposal. We only need the quantity in gallons of chlorine, sodium hydroxide and the anti-scaler monthly.?
- A8. *Estimated quantities are 40 gallons of chlorine, 4 gallons sodium hydroxide and 4 gallons of the anti-scaler monthly.*

There are no other changes at this time. Please acknowledge this addendum via Attachment D, Addenda Acknowledgement Form, in your submittal.

Thank you for your interest in The School District of Lee County.

Richard Cowie

**Richard Cowie
Procurement Agent**