



PROCUREMENT SERVICES

ADDENDUM TO CONTRACT DOCUMENTS

ADDENDUM NO.: 1

SOLICITATION NAME: ITN No. N207392RC – Generators – Maintenance, Repairs and Purchase

DATE OF ISSUE: March 26, 2021

The following information shall be included in the ITN documents and is hereby made part of the contract documents in the form of clarification, addition, deletion or revision to the contract specifications.

Proposers' questions/issues and District answers (District answers are italicized):

Q1. In order to properly quote this we will need the Amp rating needed for each ATS for each generator and if the ATS needs to be service entrance rated or not please.

A1. *This category is for budgeting purposes on potential future purchase of some aging generators. The Amp rating should match the max rated KW for each generator. These do not need to be service rated.*

There are no other changes at this time. Please acknowledge this addendum via Attachment B, Addenda Acknowledgement Form, in your submittal.

Thank you for your interest in The School District of Lee County.

Richard Cowie

**Richard Cowie
Procurement Agent**