



October 13, 2022

Matt Odachowski
Royal Plus
201 Belt Street
Snow Hill, MD 21863

**RE: Ft. Meyers Technical College
Executive Summary for School Clearance and Reoccupation
Post Restoration / Remediation Verification (PRV)**

Mr. Odachowski:

Industrial Hygiene Consulting, Corp. (IHC) is pleased to provide you this executive summary letter of substantial completion and health and safety clearance for the Hurricane Ian restoration and remediation related work performed at the Ft. Meyers Technical College campus located at 3800 Michigan Avenue in Ft Meyers, Florida. The primary health and safety clearance was performed on October 12, 2022. The post restoration inspection and clearance related work performed by IHC included the following:

- Development of the building restoration / remediation specification and standard operating procedures for the Hurricane Ian recovery effort.
- Perform ongoing monitoring of moisture conditions within the interior of the buildings to ensure the atmospheric conditions were stabilized and controlled to prevent fungal growth throughout the interior of the buildings.
- Perform visual inspection and assessment of the interior of each room within each building to ensure the indoor environmental conditions are visually clean, free of water related odors, free of significant visual water stains, physical water damage and visual fungal growth.
- Collection of air quality bioaerosol samples to verify the indoor environmental conditions are acceptable for the health and safety of all occupants (students and staff) returning to each building.

Conclusions / Summary of Findings

1. The restoration of the previously water impacted and restored portions of the property has met the outlined criteria for acceptance and PASSES the post restoration / remediation verification clearance.
2. The indoor environment of the school buildings are visually clean, free from water related odors, visually free of significant water stains and free from visual fungal growth.
3. The results of the air quality bioaerosol sampling indicated low or normal total airborne fungal counts relative to the outdoor control samples. Additionally, the fungal organism orientation of indoor air genera to the outdoor control sample air genera are similar and there is no significant dominance indoors of undesirable fungal organisms or hydrophilic fungal organisms, such as *Stachybotrys* and *Chaetomium*. See the attached laboratory data as verification of acceptable conditions.
 - The exceptions to this where fungal air samples were not collected was building G, where ongoing restoration repairs are being performed.

Recommendations (Remaining Action Items to Complete)

- A. Complete the restoration repairs in building G. Once the rooms in this building are restored, post remediation verification testing and inspection can be completed.
- B. Continue to manage water intrusion and ceiling tile replacement as necessary.

Standard of Care

Information provided in this document is based upon current and generally recognized scientific and technical understanding of the issues presented. In addition, some causes may be masked or hidden by conditions or activities in the building. As a result, the conclusions and recommendations do not guarantee that all factors have been identified and that all issues will be resolved if the recommendations are implemented. The conclusions and recommendations made in this document are our professional opinion and are based on the observations made and conditions present at the time of the investigation, discussions with individuals involved, and the results of tests and/or measurements performed. Following or implementing the recommendations does not provide complete protection from future building occupant irritation or possible health consequences that may be caused by indoor environmental conditions. No warranty is implied or intended. The report prepared by Consultant and all written documentation created by Consultant are Consultant's work product and protect by US Copyright law (17 USC 101 et seq). Provided Owner is not in material breach of this Agreement and has paid all amounts due to Owner hereunder, Consultant grants to Owner a perpetual license to use the report.

If you have any additional questions or concerns, please do not hesitate to contact me directly at 866-989-5567, ext 1.

Sincerely,

A handwritten signature in black ink that reads "Slade K. Smith". The signature is written in a cursive style and is positioned above the typed name.

Slade K. Smith, RPIH, AIEH, IICRC AMRT Instructor, IICRC Master Restorer
Industrial Hygiene Consulting, Corp. 866-989-5567



EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / miamilab@emsl.com

EMSL Order: 172205417

Customer ID: AQE63

Customer PO:

Project ID:

Attention: Lab Results

AirQuest Environmental, Inc.

6851 Southwest 45th Street

Fort Lauderdale, FL 33314

Phone: (954) 792-4549

Fax: (954) 792-2221

Collected Date: 10/12/2022

Received Date: 10/13/2022 08:00 AM

Analyzed Date: 10/13/2022

Project: 19571

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	172205417-0001 FMTC-01 75 Outdoors - North			172205417-0002 FMTC-02 75 Outdoors - West			172205417-0003 FMTC-03 75 Cafeteria			
	Spore Types	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-	-
Ascospores	11	480	10.2	19	830	17.6	-	-	-	-
Aspergillus/Penicillium	3	100	2.1	14	610	13	2	90	34.6	-
Basidiospores	25	1100	23.3	42	1800	38.2	1	40	15.4	-
Bipolaris++	1*	10*	0.2	1	40	0.8	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-	-
Cladosporium	59	2600	55.1	14	610	13	2	90	34.6	-
Curvularia	-	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-	-
Ganoderma	3	100	2.1	10	440	9.3	1	40	15.4	-
Myxomycetes++	2	90	1.9	1	40	0.8	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	1	40	0.8	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	1	40	0.8	-	-	-	-
Corynespora	-	-	-	-	-	-	-	-	-	-
Nigrospora	-	-	-	-	-	-	-	-	-	-
Pyricularia	5	200	4.2	7	300	6.4	-	-	-	-
Total Fungi	110	4720	100	109	4710	100	6	260	100	-
Hyphal Fragment	-	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	1	40	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-	-
Background (1-5)	-	2	-	-	2	-	-	1	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly Wallace, Laboratory Manager
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. **** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/13/2022 10:30 AM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / miamilab@emsl.com

EMSL Order: 172205417

Customer ID: AQE63

Customer PO:

Project ID:

Attention: Lab Results

AirQuest Environmental, Inc.

6851 Southwest 45th Street

Fort Lauderdale, FL 33314

Phone: (954) 792-4549

Fax: (954) 792-2221

Collected Date: 10/12/2022

Received Date: 10/13/2022 08:00 AM

Analyzed Date: 10/13/2022

Project: 19571

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	172205417-0004 FMTC-04 75 Kitchen			172205417-0005 FMTC-05 75 Main Office - Lobby			172205417-0006 FMTC-06 75 Main Office - Corridor			
	Spore Types	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	1*	10*	5.3	-	-	-	-
Aspergillus/Penicillium	35	1500	100	-	-	-	-	-	-	-
Basidiospores	-	-	-	-	-	-	-	-	-	-
Bipolaris++	-	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	3	100	52.6	-	-	-	-
Curvularia	-	-	-	1	40	21.1	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	1	40	21.1	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	-	-	-	-	-	-	-
Corynespora	-	-	-	-	-	-	-	-	-	-
Nigrospora	-	-	-	-	-	-	-	-	-	-
Pyricularia	-	-	-	-	-	-	-	-	-	-
Total Fungi	35	1500	100	6	190	100	-	None Detect	-	-
Hyphal Fragment	-	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-	-
Background (1-5)	-	1	-	-	1	-	-	1	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly Wallace, Laboratory Manager
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. **** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/13/2022 10:30 AM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / miamilab@emsl.com

EMSL Order: 172205417

Customer ID: AQE63

Customer PO:

Project ID:

Attention: Lab Results

AirQuest Environmental, Inc.
6851 Southwest 45th Street
Fort Lauderdale, FL 33314

Phone: (954) 792-4549

Fax: (954) 792-2221

Collected Date: 10/12/2022

Received Date: 10/13/2022 08:00 AM

Analyzed Date: 10/13/2022

Project: 19571

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	172205417-0007 FMTC-07 75 D2 - Lab			172205417-0008 FMTC-08 75 A-12 Classroom			172205417-0009 FMTC-09 75 A-2 Office			
	Spore Types	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-	-
Ascospores	2	90	12.7	-	-	-	-	-	-	-
Aspergillus/Penicillium	6	300	42.3	-	-	-	-	-	-	-
Basidiospores	5	200	28.2	2	90	52.9	2	90	20.9	
Bipolaris++	-	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	1	40	23.5	7	300	69.8	
Curvularia	1	40	5.6	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-	-
Ganoderma	1	40	5.6	1	40	23.5	1	40	9.3	
Myxomycetes++	-	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	-	-	-	-	-	-	-
Corynespora	1	40	5.6	-	-	-	-	-	-	-
Nigrospora	-	-	-	-	-	-	-	-	-	-
Pyricularia	-	-	-	-	-	-	-	-	-	-
Total Fungi	16	710	100	4	170	100	10	430	100	
Hyphal Fragment	-	-	-	-	-	-	-	-	-	-
Insect Fragment	1	40	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-	-
Background (1-5)	-	3	-	-	2	-	-	1	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly Wallace, Laboratory Manager
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. **** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/13/2022 10:30 AM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / miamilab@emsl.com

EMSL Order: 172205417

Customer ID: AQE63

Customer PO:

Project ID:

Attention: Lab Results

AirQuest Environmental, Inc.
6851 Southwest 45th Street
Fort Lauderdale, FL 33314

Phone: (954) 792-4549

Fax: (954) 792-2221

Collected Date: 10/12/2022

Received Date: 10/13/2022 08:00 AM

Analyzed Date: 10/13/2022

Project: 19571

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	172205417-0010 FMTC-10 75 A-5 Hallway			172205417-0011 FMTC-11 75 B-1A Classroom			172205417-0012 FMTC-12 75 B-1M Office		
	Spore Types	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³
Alternaria (Ulocladium)	-	-	-	1*	10*	0.8	-	-	-
Ascospores	-	-	-	10	440	33.8	10	440	37
Aspergillus/Penicillium	-	-	-	6	300	23.1	6	300	25.2
Basidiospores	-	-	-	7	300	23.1	6	300	25.2
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	5	200	15.4	1	40	3.4
Curvularia	-	-	-	-	-	-	1*	10*	0.8
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	1	40	3.1	1	40	3.4
Myxomycetes++	-	-	-	-	-	-	1	40	3.4
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	-	-	-	1*	10*	0.8
Corynespora	-	-	-	-	-	-	-	-	-
Nigrospora	-	-	-	-	-	-	1*	10*	0.8
Pyricularia	-	-	-	1*	10*	0.8	-	-	-
Total Fungi	-	None Detect	-	31	1300	100	28	1190	100
Hyphal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	2	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	2	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly Wallace, Laboratory Manager
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. **** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/13/2022 10:30 AM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / miamilab@emsl.com

EMSL Order: 172205417

Customer ID: AQE63

Customer PO:

Project ID:

Attention: Lab Results

AirQuest Environmental, Inc.
6851 Southwest 45th Street
Fort Lauderdale, FL 33314

Phone: (954) 792-4549

Fax: (954) 792-2221

Collected Date: 10/12/2022

Received Date: 10/13/2022 08:00 AM

Analyzed Date: 10/13/2022

Project: 19571

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	172205417-0013 FMTC-13 75 Outdoors - West			172205417-0014 FMTC-14 75 Outdoors - South			172205417-0015 FMTC-15 75 F-20 Staff Room		
	Spore Types	Raw Count	Count/M³	% of Total	Raw Count	Count/M³	% of Total	Raw Count	Count/M³
Alternaria (Ulocladium)	1*	10*	0.3	-	-	-	-	-	-
Ascospores	12	520	14.5	17	740	31.5	-	-	-
Aspergillus/Penicillium	3	100	2.8	7	300	12.8	3	100	71.4
Basidiospores	17	740	20.6	9	400	17	-	-	-
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-
Cladosporium	43	1900	52.9	14	610	26	-	-	-
Curvularia	2	90	2.5	1*	10*	0.4	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	4	200	8.5	-	-	-
Myxomycetes++	3	100	2.8	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Cercospora++	2	90	2.5	2	90	3.8	-	-	-
Corynespora	-	-	-	-	-	-	-	-	-
Nigrospora	1	40	1.1	-	-	-	1	40	28.6
Pyricularia	-	-	-	-	-	-	-	-	-
Total Fungi	84	3590	100	54	2350	100	4	140	100
Hyphal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	2	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	2	-	-	2	-	-	3	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly Wallace, Laboratory Manager
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. **** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/13/2022 10:30 AM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / miamilab@emsl.com

EMSL Order: 172205417
Customer ID: AQE63
Customer PO:
Project ID:

Attention: Lab Results AirQuest Environmental, Inc. 6851 Southwest 45th Street Fort Lauderdale, FL 33314	Phone: (954) 792-4549 Fax: (954) 792-2221 Collected Date: 10/12/2022 Received Date: 10/13/2022 08:00 AM Analyzed Date: 10/13/2022
Project: 19571	

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	172205417-0016 FMTC-16 75 F-14 Class Room			172205417-0017 FMTC-17 75 F-18 Lab			172205417-0018 FMTC-18 75 H-3 Class Room			
	Spore Types	Raw Count	Count/M³	% of Total	Raw Count	Count/M³	% of Total	Raw Count	Count/M³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	-	-	-	-
Aspergillus/Penicillium	-	-	-	2	90	90	1	40	22.2	
Basidiospores	-	-	-	-	-	-	3	100	55.6	
Bipolaris++	1*	10*	4.8	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-	-
Cladosporium	4	200	95.2	1*	10*	10	-	-	-	-
Curvularia	-	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	-	-	-	-	-	-	-
Corynespora	-	-	-	-	-	-	-	-	-	-
Nigrospora	-	-	-	-	-	-	-	-	-	-
Pyricularia	-	-	-	-	-	-	1	40	22.2	
Total Fungi	5	210	100	3	100	100	5	180	100	
Hyphal Fragment	-	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-	-
Background (1-5)	-	2	-	-	2	-	-	3	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly A. Wallace

 Kimberly Wallace, Laboratory Manager
 or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. **** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/13/2022 10:30 AM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / miamilab@emsl.com

EMSL Order: 172205417

Customer ID: AQE63

Customer PO:

Project ID:

Attention: Lab Results

AirQuest Environmental, Inc.

6851 Southwest 45th Street

Fort Lauderdale, FL 33314

Phone: (954) 792-4549

Fax: (954) 792-2221

Collected Date: 10/12/2022

Received Date: 10/13/2022 08:00 AM

Analyzed Date: 10/13/2022

Project: 19571

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	172205417-0019 FMTC-19 75 H-6 Lab			172205417-0020 FMTC-20 75 H-12 Lab		
	Spore Types	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³
Alternaria (Ulocladium)	-	-	-	-	-	-
Ascospores	1	40	80	1	40	9.8
Aspergillus/Penicillium	-	-	-	2	90	22
Basidiospores	-	-	-	-	-	-
Bipolaris++	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-
Cladosporium	-	-	-	3	100	24.4
Curvularia	1*	10*	20	-	-	-
Epicoccum	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-
Ganoderma	-	-	-	2	90	22
Myxomycetes++	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-
Rust	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-
Cercospora++	-	-	-	1	40	9.8
Corynespora	-	-	-	-	-	-
Nigrospora	-	-	-	1	40	9.8
Pyricularia	-	-	-	1*	10*	2.4
Total Fungi	2	50	100	11	410	100
Hyphal Fragment	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-
Pollen	1*	10*	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-
Background (1-5)	-	1	-	-	2	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly Wallace, Laboratory Manager
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. **** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/13/2022 10:30 AM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com

Chain of Custody
Laboratory Sample Submittal Form

AIR QUEST

ENVIRONMENTAL, INC.

6851 SW 45th Street
Fort Lauderdale, Florida 33314

Phone: (954) 792-4549
Fax: (954) 792-2221
Toll Free: (877) 247-8146
Email: labresults@airquestinc.com
TAT: 3 Hr. ___; 6 Hr. ___; 24 Hr. ___; Other ___

Sample Date: 10-12-22
Project Number: 19571
Site Address: FMTc-3800 Michigan Ave
Fort Myers, FL 33916
Collected By: George Raimundo

172205417


Code	Description	Bulk Sample Type
TL	Tape Lift Sample for Fungi	
SW	Swab Sample for Fungi	
WP	Wipe Sample for Fungi	
BF	Bulk Sample for Fungi	
BB	Bulk Sample for E. Coli/Total Coliform	
Other		
Other		
Other		

Code	Description	Air Sample Type
AOC	AirCell Sample for Fungi & Particulate	
AS	N6 Sample for Viable Fungi	
ASB	N6 Sample for Bacteria	
Other		

Item	Code	Sample Number	Description	Location	Volume/Quantity /Area	Comments
1	ACC	FMTc-01	Base line Comparison	Outdoors-NORTH	75 Lt.	
2	↓	FMTc-02	↓	Outdoors-West	↓	
3	↓	FMTc-03	Breathing Zone	Cafeteria	↓	
4	↓	FMTc-04	↓	Kitchen	↓	
5	↓	FMTc-05	↓	Main Office-Lobby	↓	
6	↓	FMTc-06	↓	Main Office-Corridor	↓	
7	↓	FMTc-07	↓	D2-Lab	↓	
8	↓	FMTc-08	↓	A-12 Classroom	↓	
9	↓	FMTc-09	↓	A-2 OFFICE	↓	
10	↓	FMTc-10	↓	A-5 Hallway	↓	

Relinquished by: George Raimundo Date & Time: 10-12-22 @ 13:00
 Received by: _____ Date & Time: _____
 Relinquished by: _____ Date & Time: _____
 Received by: _____ Date & Time: _____

Initials: GR Tracking # _____
 Fedex: _____
 Hand Counted



Chain of Custody
Laboratory Sample Submittal Form

AIR QUEST

ENVIRONMENTAL, INC.

6851 SW 45th Street
Fort Lauderdale, Florida 33314

Phone: (954) 792-4549
Fax: (954) 792-2221
Toll Free: (877) 247-8146
Email: labresults@airquestinc.com
TAT: 3 Hr. ; 6 Hr. ; 24 Hr. ; Other

Sample Date: 10-12-22
Project Number: 19571
Site Address: FMTc-5800 Michigan Ave
Fort Myers FL 33916
Collected By: George Rainwold

Bulk Sample Type	
Code	Description
TL	Tape Lift Sample for Fungi
SW	Swab Sample for Fungi
W/P	Wipe Sample for Fungi
BF	Bulk Sample for Fungi
BB	Bulk Sample for E. Coli/Total Coliform
Other	
Other	
Other	

Air Sample Type	
Code	Description
AOC	Air-Cell Sample for Fungi & Particulate
AS	N6 Sample for Viable Fungi
ASB	N6 Sample for Bacteria
Other	

Item	Code	Sample Number	Description	Location	Volume/Quantity /Area	Comments
1.	AOC	FMTc-11	Breathing Zone	B-1A Classroom	75 L	
2		FMTc-12	↓	B-1M OFFICE	↓	
3		FMTc-13	Baseline Comparison	Outdoors - West	↓	
4		FMTc-14	↓	Outdoors - South	↓	
5		FMTc-15	Breathing Zone	F-20 Staff Room	↓	
6		FMTc-16	↓	F-14 Class Room	↓	
7		FMTc-17	↓	F-18 Lab	↓	
8		FMTc-18	↓	H-3 Class Room	↓	
9		FMTc-19	↓	H-6 Lab	↓	
10		FMTc-20	↓	H-12 Lab	↓	

Relinquished by: George Rainwold Date & Time: 10-22-22 @ 13:00 Initials: GR Tracking # _____

Received by: _____ Date & Time: _____

Relinquished by: _____ Date & Time: _____

Received by: _____ Date & Time: _____

FedEx: _____

Hand Couriered

No apparent remediation (NAR)
Acoustic ceiling tile (ACT)

Daily Summary

School: FMTC
Date: 10/12/22

Room / Area:	PRV	NOTES
<u>J</u>	<input checked="" type="checkbox"/> Passed <input type="checkbox"/> Failed	<u>No apparent remediation (NAR) Ceiling tiles stained (3)</u>
<u>E</u>	<input checked="" type="checkbox"/> Passed <input type="checkbox"/> Failed	<u>NAR</u>
<u>C</u>	<input checked="" type="checkbox"/> Passed <input type="checkbox"/> Failed	<u>C-31 stained CT (1); NAR</u>
<u>D</u>	<input checked="" type="checkbox"/> Passed <input type="checkbox"/> Failed	<u>No apparent remediation (NAR)</u>
<u>A</u>	<input checked="" type="checkbox"/> Passed <input type="checkbox"/> Failed	<u>NAR; stained ceiling tiles</u>
<u>B</u>	<input checked="" type="checkbox"/> Passed <input type="checkbox"/> Failed	<u>NAR</u>
<u>G</u>	<input type="checkbox"/> Passed <input checked="" type="checkbox"/> Failed	<u>Wet/blow-out ACT throughout</u>
<u>F</u>	<input checked="" type="checkbox"/> Passed <input type="checkbox"/> Failed	<u>Some stained ACT</u>
<u>H</u>	<input checked="" type="checkbox"/> Passed <input type="checkbox"/> Failed	<u>"</u>
<u>L</u>	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	<u>NO ACCESS (construction)</u>
	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	
	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	
	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	
	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	
	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	
	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	
	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	
	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	
	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	
	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	
	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	
	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	
	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	

✓

No apparent remediation (NAR)
Acoustic ceiling tile (ACT)

Daily Summary

School: FMTC

Date: 10/12/22

Room / Area:	PRV	NOTES
<u>J</u>	<input checked="" type="checkbox"/> Passed <input type="checkbox"/> Failed	<u>No apparent Remediation (NAR) Ceiling tiles stained (3)</u>
<u>E</u>	<input checked="" type="checkbox"/> Passed <input type="checkbox"/> Failed	<u>NAR</u>
<u>C</u>	<input checked="" type="checkbox"/> Passed <input type="checkbox"/> Failed	<u>C-31 stained CT (1); NAR</u>
<u>D</u>	<input checked="" type="checkbox"/> Passed <input type="checkbox"/> Failed	<u>No apparent remediation (NAR)</u>
<u>A</u>	<input checked="" type="checkbox"/> Passed <input type="checkbox"/> Failed	<u>NAR; stained ceiling tiles</u>
<u>B</u>	<input checked="" type="checkbox"/> Passed <input type="checkbox"/> Failed	<u>NAR</u>
<u>G</u>	<input type="checkbox"/> Passed <input checked="" type="checkbox"/> Failed	<u>Wet/blow-out ACT throughout</u>
<u>F</u>	<input checked="" type="checkbox"/> Passed <input type="checkbox"/> Failed	<u>Some stained ACT</u>
<u>H</u>	<input checked="" type="checkbox"/> Passed <input type="checkbox"/> Failed	<u>"</u>
<u>L</u>	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	<u>NO ACCESS (construction)</u>
_____	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	_____
_____	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	_____
_____	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	_____
_____	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	_____
_____	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	_____
_____	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	_____
_____	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	_____
_____	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	_____
_____	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	_____
_____	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	_____
_____	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	_____
_____	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	_____
_____	<input type="checkbox"/> Passed <input type="checkbox"/> Failed	_____

✓

Date: 10/12/22

SCHOOL: FMTC
Room: Outdoor, North + West

Temp.	rH%	Dew Point
81	85	75

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- North Wall Clean Stained VMG
- East Wall Clean Stained VMG
- South Wall Clean Stained VMG
- West Wall Clean Stained VMG

Flooring:

- Clean Wet
- Dirty Dry
- VMG

Air Sampling:

- YES
- NO

- AOC
- Date: ___/___/___

NOTES:

Date: 10/12/22

SCHOOL:

FMTC

Room:

Bldg "E"
Kitchen

Temp.	rH%	Dew Point
87	72	77

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- | | | | |
|------------|---|----------------------------------|------------------------------|
| North Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| East Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| South Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| West Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |

Flooring:

- | | |
|---|------------------------------|
| <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Wet |
| <input type="checkbox"/> Dirty | <input type="checkbox"/> Dry |
| <input type="checkbox"/> VMG | |

Air Sampling:

- YES NO

AOC

Date: 10/12/22

NOTES:

No apparent remediation

SCHOOL:

Fort Myers Technical College

Date: 10/12/22

Room:

Dining Room
J-1

Temp.	rH%	Dew Point
83	84	77

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles: (CCT)

Walls:

- | | | | | |
|---|------------|---|----------------------------------|------------------------------|
| <input type="checkbox"/> Clean | North Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| <input checked="" type="checkbox"/> Remaining Stained | East Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| <input type="checkbox"/> Remaining VMG | South Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| | West Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |

Flooring:

- Clean
- Dirty
- VMG
- Wet
- Dry

Air Sampling:

YES

~~VMG~~

AOC

Date: 10/12/22

NOTES:

ACT: North wall, < 1 ft²; N. wall < 1 ft² - both dry
South wall < 1 ft².

No apparent remediation

Date: 10/12/22

SCHOOL: FMTC

Room: Bldg "C" office

Temp.	rH%	Dew Point
90	44	66

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles: (ct)

Walls:

- | | | | | |
|---|------------|---|----------------------------------|------------------------------|
| <input type="checkbox"/> Clean | North Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| <input checked="" type="checkbox"/> Remaining Stained | East Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| <input type="checkbox"/> Remaining VMG | South Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| | West Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |

Flooring:

- | | |
|---|------------------------------|
| <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Wet |
| <input type="checkbox"/> Dirty | <input type="checkbox"/> Dry |
| <input type="checkbox"/> VMG | |

Air Sampling: YES NO

AOC

Date: 10/12/22

NOTES:

No apparent remediation
ACT: C-31 stained tile

Date: 10/12/22

SCHOOL: FMTC

Room: D-1

Temp.	rH%	Dew Point
95	37	63

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- North Wall Clean Stained VMG
- East Wall Clean Stained VMG
- South Wall Clean Stained VMG
- West Wall Clean Stained VMG

Flooring:

- Clean Wet
- Dirty Dry
- VMG

Air Sampling:

- YES
- NO

A O C

Date: __/__/__

NOTES:

Date: 10/12/22

SCHOOL: FMTC
Room: D-2

Temp.	rH%	Dew Point
99	34	67

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- North Wall Clean Stained VMG
- East Wall Clean Stained VMG
- South Wall Clean Stained VMG
- West Wall Clean Stained VMG

Flooring:

- Clean Wet
- Dirty Dry
- VMG

Air Sampling:

- YES NO

A O C

Date: 10/12/22

NOTES:

Date: 10/12/22

SCHOOL:

FMTC

Room:

D-2N

Temp.	rH%	Dew Point
92	49	67

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- North Wall Clean Stained VMG
- East Wall Clean Stained VMG
- South Wall Clean Stained VMG
- West Wall Clean Stained VMG

Flooring:

- Clean Wet
- Dirty Dry
- VMG

Air Sampling:

- YES
- NO

A O C

Date: __/__/__

NOTES:

Date: ___/___/___

SCHOOL:

FMTC

Room:

D-3 / D-4

Temp.	rH%	Dew Point
68	74	68

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- North Wall Clean Stained VMG
- East Wall Clean Stained VMG
- South Wall Clean Stained VMG
- West Wall Clean Stained VMG

Flooring:

- Clean Wet
- Dirty Dry
- VMG

Air Sampling:

- YES NO

A O C

Date: ___/___/___

NOTES:

Very little cellulose; no ACT or drywall.

Date: 10/12/22

SCHOOL: EMTC
Room: Bldg A

Temp.	rH%	Dew Point
89	55	72

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- | | | | |
|------------|---|----------------------------------|------------------------------|
| North Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| East Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| South Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| West Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |

Flooring:

- Clean
- Dirty
- VMG
- Wet
- Dry

Air Sampling:

- YES
- NO

AOC

Date: 10/12/22

NOTES:

~~Rm. A-3 = no access~~

office A-3E - stained ceiling tile < 1 ft²

Bathroom across from A-3B - stained ceiling tile

A-6 - stained ceiling tile < 1 ft²

A-8: stained ceiling tiles (2) ~ 3 ft²

Date: 10/12/22

SCHOOL: FMTC
Room: ~~1300~~ B

Temp.	rH%	Dew Point
84	72	73

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- | | | | |
|------------|---|----------------------------------|------------------------------|
| North Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| East Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| South Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| West Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |

Flooring:

- Clean
- Dirty
- VMG
- Wet
- Dry

Air Sampling:

- YES
- NO
- A O C
- Date: 10/12/22

NOTES:

Date: 10/12/22

SCHOOL: FMTC
Room: G-1

Temp.	rH%	Dew Point
97	33	63

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Dry

Walls:

- | | | | |
|------------|---|----------------------------------|------------------------------|
| North Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| East Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| South Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| West Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |

Flooring:

- | | |
|---|---|
| <input type="checkbox"/> Clean | <input checked="" type="checkbox"/> Wet |
| <input checked="" type="checkbox"/> Dirty | <input type="checkbox"/> Dry |
| <input type="checkbox"/> VMG | |

Air Sampling:

- YES NO

AOC

Date: ___/___/___

NOTES:

one (1) blown-out ceiling tile, dry
Dirty floor throughout

SCHOOL:

FAMTC

Date: 10/12/22

Room:

G-2

Temp.	rH%	Dew Point
110	31	70

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- ~~North Wall~~ Clean Stained VMG
- ~~East Wall~~ Clean Stained VMG
- ~~South Wall~~ Clean Stained VMG
- ~~West Wall~~ Clean Stained VMG

Flooring:

- Clean Wet
- Dirty Dry
- VMG

Air Sampling:

- YES NO

A O C

Date: ___/___/___

NOTES:

G-2B: 5 ft² wet drywall ceiling

SCHOOL:

FMTC

Date: 10/12/22

Room:

G-3

Temp.	rH%	Dew Point
96	43	70

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- | | | | |
|------------|---|----------------------------------|------------------------------|
| North Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| East Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| South Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| West Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |

Flooring:

- | | |
|---|------------------------------|
| <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Wet |
| <input type="checkbox"/> Dirty | <input type="checkbox"/> Dry |
| <input type="checkbox"/> VMG | |

Air Sampling:

- YES NO

A O C

Date: ___/___/___

NOTES:

Date: 10/12/22

SCHOOL: FMTC
Room: G-4

Temp.	rH%	Dew Point
96	43	70

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- North Wall Clean Stained VMG
- East Wall Clean Stained VMG
- South Wall Clean Stained VMG
- West Wall Clean Stained VMG

Flooring:

- Clean
- Dirty
- VMG

Wet
 Pool

Air Sampling:

YES NO

AOC

Date: ___/___/___

NOTES:

60 2x4 ACT, water-damaged 10x-floor

Some wet

50 stained ACT

Date: 10/12/22

SCHOOL: FMTC
Room: G-5

Temp.	rH%	Dew Point
88	55	71

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- | | | | |
|------------|--------------------------------|----------------------------------|------------------------------|
| North Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| East Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| South Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| West Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |

Flooring:

- Clean
- Dirty
- VMG
- Wet
- Dry

Air Sampling: YES NO

AOC

Date: ___/___/___

NOTES:

2x4 ACT on-floor, some wet

Date: 10/12/22

SCHOOL: EMTC
Room: G-6

Temp.	rH%	Dew Point
88	55	71

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- | | | | |
|------------|---|----------------------------------|------------------------------|
| North Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| East Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| South Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| West Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |

Flooring:

- Clean
- Dirty
- VMG
- Wet
- Dry

Air Sampling:

- YES NO

A O C

Date: ___/___/___

NOTES:

VMG - classroom in G-6
60 2x4" ACT, water-damaged / on floor,
some wet
50 stained ACT

ACT - acoustic ceiling tile

Date: 10/12/22

SCHOOL: FMTC

Room: F

Temp.	rH%	Dew Point
92	59	75

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- North Wall Clean Stained VMG
- East Wall Clean Stained VMG
- South Wall Clean Stained VMG
- West Wall Clean Stained VMG

Flooring:

- Clean Wet
- Dirty Dry
- VMG

Air Sampling:

- YES NO

AOC

Date: / /

NOTES:

F-18B water-damaged ACT

F-13A: "

F-12: staining on concrete slab + vinyl coating

F-19: two (2) stained ACT

Date: 10/12/22

SCHOOL: FMTC

Room: H

Temp.	rH%	Dew Point
85	60	68

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- North Wall Clean Stained VMG
- East Wall Clean Stained VMG
- South Wall Clean Stained VMG
- West Wall Clean Stained VMG

Flooring:

- Clean Wet
- Dirty Dry
- VMG

Air Sampling:

- YES NO

AOC

Date: 10/12/22

NOTES:

H-12: four (4) water-damaged ACT, dry
H-12E: one (1) ACT, dry, stained
H-4F: ~~one~~ stained ACT, dry - three (3)
H-1A: 4 stained ACT
H-7: blown-out ACT (1)
H-17: stained ACT (2)
H-16C: three⁽³⁾ stained ACT

Date: 10/12/22

SCHOOL:

FMTC

Room:

Carpentry pav.

Temp.	rH%	Dew Point

NO INDOOR
AREAS

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- | | | | |
|------------|--------------------------------|----------------------------------|------------------------------|
| North Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| East Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| South Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| West Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |

Storage
building
not
included

Flooring:

- | | |
|--------------------------------|------------------------------|
| <input type="checkbox"/> Clean | <input type="checkbox"/> Wet |
| <input type="checkbox"/> Dirty | <input type="checkbox"/> Dry |
| <input type="checkbox"/> VMG | |

Air Sampling:

- YES NO

A O C

Date: ___/___/___

NOTES:
