



October 15, 2022

Matt Odachowski  
Royal Plus  
201 Belt Street  
Snow Hill, MD 21863

**RE: Cypress Lake Middle School  
Executive Summary for School Clearance and Reoccupation  
Post Restoration / Remediation Verification (PRV)**

Mr. Odachowski:

Industrial Hygiene Consulting, Corp. (IHC) is pleased to provide you this executive summary letter of substantial completion and health and safety clearance for the Hurricane Ian restoration and remediation related work performed at the Cypress Lake Middle School campus located at 8901 Cypress Lake Drive in Ft Meyers, Florida. The primary health and safety clearance was performed on October 14, 2022. The post restoration inspection and clearance related work performed by IHC included the following:

- Development of the building restoration / remediation specification and standard operating procedures for the Hurricane Ian recovery effort.
- Perform ongoing monitoring of moisture conditions within the interior of the buildings to ensure the atmospheric conditions were stabilized and controlled to prevent fungal growth throughout the interior of the buildings.
- Perform visual inspection and assessment of the interior of each room within each building to ensure the indoor environmental conditions are visually clean, free of water related odors, free of significant visual water stains, physical water damage and visual fungal growth.
- Collection of air quality bioaerosol samples to verify the indoor environmental conditions are acceptable for the health and safety of all occupants (students and staff) returning to each building.

### Conclusions / Summary of Findings

1. The restoration of the previously water impacted and restored portions of the property has met the outlined criteria for acceptance and PASSES the post restoration / remediation verification clearance.
2. The indoor environment of the school buildings are visually clean, free from water related odors, visually free of significant water stains and free from visual fungal growth.
3. The results of the air quality bioaerosol sampling indicated low or normal total airborne fungal counts relative to the outdoor control samples. Additionally, the fungal organism orientation of indoor air genera to the outdoor control sample air genera are similar and there is no significant dominance indoors of undesirable fungal organisms or hydrophilic fungal organisms, such as *Stachybotrys* and *Chaetomium*. See the attached laboratory data as verification of acceptable conditions.
  - The exceptions to this where the fungal air counts were elevated and not consistent with passing criteria were in the girl's locker room and classroom 301.
  - The gym was not evaluated and no fungal air samples were not collected due to ongoing restoration repairs being performed

### Recommendations (Remaining Action Items to Complete)

- A. Reclean the rooms and areas that did not pass air quality testing (girl's locker room and classroom 301). Once recleaned the PRV retesting will be performed.
- B. Complete the restoration repairs in the gym. Once the gym is restored, post remediation verification testing and inspection can be completed.
- C. Continue to manage water intrusion and ceiling tile replacement as necessary.

## Standard of Care

Information provided in this document is based upon current and generally recognized scientific and technical understanding of the issues presented. In addition, some causes may be masked or hidden by conditions or activities in the building. As a result, the conclusions and recommendations do not guarantee that all factors have been identified and that all issues will be resolved if the recommendations are implemented. The conclusions and recommendations made in this document are our professional opinion and are based on the observations made and conditions present at the time of the investigation, discussions with individuals involved, and the results of tests and/or measurements performed. Following or implementing the recommendations does not provide complete protection from future building occupant irritation or possible health consequences that may be caused by indoor environmental conditions. No warranty is implied or intended. The report prepared by Consultant and all written documentation created by Consultant are Consultant's work product and protect by US Copyright law (17 USC 101 et seq). Provided Owner is not in material breach of this Agreement and has paid all amounts due to Owner hereunder, Consultant grants to Owner a perpetual license to use the report.

If you have any additional questions or concerns, please do not hesitate to contact me directly at 866-989-5567, ext 1.

Sincerely,

A handwritten signature in black ink that reads "Slade K. Smith". The signature is written in a cursive style and is positioned above the typed name.

Slade K. Smith, RPIH, AIEH, IICRC AMRT Instructor, IICRC Master Restorer  
Industrial Hygiene Consulting, Corp. 866-989-5567



# EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / [miamilab@emsl.com](mailto:miamilab@emsl.com)

EMSL Order: 172205469

Customer ID: AQE63

Customer PO:

Project ID:

**Attention:** Lab Results

AirQuest Environmental, Inc.

6851 Southwest 45th Street

Fort Lauderdale, FL 33314

**Phone:** (954) 792-4549

**Fax:** (954) 792-2221

**Collected Date:** 10/14/2022

**Received Date:** 10/15/2022 07:00 AM

**Analyzed Date:** 10/15/2022

**Project:** 8901 Cypress Lake Dr. Fort Myers, FL 33919 #19571

### Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	172205469-0001			172205469-0002			172205469-0003		
Client Sample ID:	CLMS-01			CLMS-02			CLMS-03		
Volume (L):	75			75			75		
Sample Location:	Outdoors-North			Main Office-Entrance			Main Office -Rear		
Spore Types	Raw Count	Count/M <sup>3</sup>	% of Total	Raw Count	Count/M <sup>3</sup>	% of Total	Raw Count	Count/M <sup>3</sup>	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	7	300	9.2	-	-	-	-	-	-
Aspergillus/Penicillium	20	870	26.8	2	90	52.9	-	-	-
Basidiospores	16	700	21.5	-	-	-	-	-	-
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-
Cladosporium	30	1300	40	1	40	23.5	-	-	-
Curvularia	-	-	-	-	-	-	1	40	50
Epicoccum	1	40	1.2	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-
Ganoderma	1	40	1.2	-	-	-	-	-	-
Myxomycetes++	-	-	-	1	40	23.5	-	-	-
Pithomyces++	-	-	-	-	-	-	1	40	50
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Beltrania	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	-	-	-	-	-	-
Pyricularia	-	-	-	-	-	-	-	-	-
<b>Total Fungi</b>	<b>75</b>	<b>3250</b>	<b>100</b>	<b>4</b>	<b>170</b>	<b>100</b>	<b>2</b>	<b>80</b>	<b>100</b>
Hyphal Fragment	-	-	-	1	40	-	1	40	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	2	-	-	2	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly Wallace, Laboratory Manager  
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. \*\*\*\* Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/15/2022 12:53 PM

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)



# EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / [miamilab@emsl.com](mailto:miamilab@emsl.com)

EMSL Order: 172205469

Customer ID: AQE63

Customer PO:

Project ID:

**Attention:** Lab Results

AirQuest Environmental, Inc.

6851 Southwest 45th Street

Fort Lauderdale, FL 33314

**Phone:** (954) 792-4549

**Fax:** (954) 792-2221

**Collected Date:** 10/14/2022

**Received Date:** 10/15/2022 07:00 AM

**Analyzed Date:** 10/15/2022

**Project:** 8901 Cypress Lake Dr. Fort Myers, FL 33919 #19571

### Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	172205469-0004 CLMS-04 75 Media Center			172205469-0005 CLMS-05 75 Cafeteria			172205469-0006 CLMS-06 75 Staff Dining			
	Spore Types	Raw Count	Count/M <sup>3</sup>	% of Total	Raw Count	Count/M <sup>3</sup>	% of Total	Raw Count	Count/M <sup>3</sup>	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	1	40	16.7	-	-	-	-
Aspergillus/Penicillium	1	40	28.6	-	-	-	7	300	63.8	-
Basidiospores	-	-	-	-	-	-	2	90	19.1	-
Bipolaris++	-	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-	-
Cladosporium	3	100	71.4	5	200	83.3	-	-	-	-
Curvularia	-	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	1	40	8.5	-
Myxomycetes++	-	-	-	-	-	-	1	40	8.5	-
Pithomyces++	-	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-	-
Beltrania	-	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	-	-	-	-	-	-	-
Pyricularia	-	-	-	-	-	-	-	-	-	-
<b>Total Fungi</b>	<b>4</b>	<b>140</b>	<b>100</b>	<b>6</b>	<b>240</b>	<b>100</b>	<b>11</b>	<b>470</b>	<b>100</b>	
Hyphal Fragment	-	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-	-
Background (1-5)	-	2	-	-	1	-	-	1	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly Wallace, Laboratory Manager  
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. \*\*\*\* Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/15/2022 12:53 PM

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)



# EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / [miamilab@emsl.com](mailto:miamilab@emsl.com)

EMSL Order: 172205469

Customer ID: AQE63

Customer PO:

Project ID:

**Attention:** Lab Results

AirQuest Environmental, Inc.

6851 Southwest 45th Street

Fort Lauderdale, FL 33314

**Phone:** (954) 792-4549

**Fax:** (954) 792-2221

**Collected Date:** 10/14/2022

**Received Date:** 10/15/2022 07:00 AM

**Analyzed Date:** 10/15/2022

**Project:** 8901 Cypress Lake Dr. Fort Myers, FL 33919 #19571

### Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	172205469-0007 CLMS-07 75 301-Classroom			172205469-0008 CLMS-08 75 406-Classroom			172205469-0009 CLMS-09 75 403-Classroom			
	Spore Types	Raw Count	Count/M <sup>3</sup>	% of Total	Raw Count	Count/M <sup>3</sup>	% of Total	Raw Count	Count/M <sup>3</sup>	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	1	40	25	1	40	28.6	
Aspergillus/Penicillium	21	920	50.3	1	40	25	3	100	71.4	
Basidiospores	5	200	10.9	-	-	-	-	-	-	
Bipolaris++	-	-	-	-	-	-	-	-	-	
Chaetomium++	-	-	-	-	-	-	-	-	-	
Cladosporium	11	480	26.2	-	-	-	-	-	-	
Curvularia	2	90	4.9	1	40	25	-	-	-	
Epicoccum	-	-	-	-	-	-	-	-	-	
Fusarium++	-	-	-	-	-	-	-	-	-	
Ganoderma	-	-	-	-	-	-	-	-	-	
Myxomycetes++	1*	10*	0.5	-	-	-	-	-	-	
Pithomyces++	-	-	-	1	40	25	-	-	-	
Rust	-	-	-	-	-	-	-	-	-	
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-	
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-	
Unidentifiable Spores	-	-	-	-	-	-	-	-	-	
Zygomycetes	-	-	-	-	-	-	-	-	-	
Beltrania	1	40	2.2	-	-	-	-	-	-	
Cercospora++	-	-	-	-	-	-	-	-	-	
Pyricularia	2	90	4.9	-	-	-	-	-	-	
<b>Total Fungi</b>	<b>43</b>	<b>1830</b>	<b>100</b>	<b>4</b>	<b>160</b>	<b>100</b>	<b>4</b>	<b>140</b>	<b>100</b>	
Hyphal Fragment	-	-	-	-	-	-	-	-	-	
Insect Fragment	-	-	-	-	-	-	-	-	-	
Pollen	-	-	-	-	-	-	-	-	-	
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-	
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-	
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-	
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-	
Background (1-5)	-	1	-	-	2	-	-	1	-	

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly Wallace, Laboratory Manager  
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. \*\*\*\* Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/15/2022 12:53 PM

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)



# EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / [miamilab@emsl.com](mailto:miamilab@emsl.com)

EMSL Order: 172205469

Customer ID: AQE63

Customer PO:

Project ID:

**Attention:** Lab Results

AirQuest Environmental, Inc.

6851 Southwest 45th Street

Fort Lauderdale, FL 33314

**Phone:** (954) 792-4549

**Fax:** (954) 792-2221

**Collected Date:** 10/14/2022

**Received Date:** 10/15/2022 07:00 AM

**Analyzed Date:** 10/15/2022

**Project:** 8901 Cypress Lake Dr. Fort Myers, FL 33919 #19571

### Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	172205469-0010 CLMS-10 75 501-Classroom			172205469-0011 CLMS-11 75 504-Classroom			172205469-0012 CLMS-12 75 601-Classroom			
	Spore Types	Raw Count	Count/M <sup>3</sup>	% of Total	Raw Count	Count/M <sup>3</sup>	% of Total	Raw Count	Count/M <sup>3</sup>	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	-	-	-	-
Aspergillus/Penicillium	-	-	-	-	-	-	2	90	42.9	-
Basidiospores	-	-	-	2	90	100	-	-	-	-
Bipolaris++	-	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	-	-	-	-	-	-	-
Curvularia	-	-	-	-	-	-	1	40	19	-
Epicoccum	-	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	1	40	19	-
Myxomycetes++	-	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	1	40	19	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-	-
Beltrania	-	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	-	-	-	-	-	-	-
Pyricularia	-	-	-	-	-	-	-	-	-	-
<b>Total Fungi</b>	-	<b>None Detect</b>	-	<b>2</b>	<b>90</b>	<b>100</b>	<b>5</b>	<b>210</b>	<b>100</b>	-
Hyphal Fragment	-	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	2	90	-	-
Pollen	-	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-	-
Background (1-5)	-	1	-	-	1	-	-	1	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly Wallace, Laboratory Manager  
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/15/2022 12:53 PM

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)



# EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / [miamilab@emsl.com](mailto:miamilab@emsl.com)

EMSL Order: 172205469

Customer ID: AQE63

Customer PO:

Project ID:

**Attention:** Lab Results

AirQuest Environmental, Inc.

6851 Southwest 45th Street

Fort Lauderdale, FL 33314

**Phone:** (954) 792-4549

**Fax:** (954) 792-2221

**Collected Date:** 10/14/2022

**Received Date:** 10/15/2022 07:00 AM

**Analyzed Date:** 10/15/2022

**Project:** 8901 Cypress Lake Dr. Fort Myers, FL 33919 #19571

### Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	172205469-0013 CLMS-13 75 803-Classroom			172205469-0014 CLMS-14 75 811-Classroom			172205469-0015 CLMS-15 75 814-Classroom		
Spore Types	Raw Count	Count/M <sup>3</sup>	% of Total	Raw Count	Count/M <sup>3</sup>	% of Total	Raw Count	Count/M <sup>3</sup>	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	1	40	14.3
Aspergillus/Penicillium	1	40	15.4	-	-	-	4	200	71.4
Basidiospores	-	-	-	-	-	-	-	-	-
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-
Cladosporium	2	90	34.6	7	300	61.2	-	-	-
Curvularia	1	40	15.4	3	100	20.4	1	40	14.3
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-
Ganoderma	2	90	34.6	-	-	-	-	-	-
Myxomycetes++	-	-	-	2	90	18.4	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Beltrania	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	-	-	-	-	-	-
Pyricularia	-	-	-	-	-	-	-	-	-
<b>Total Fungi</b>	<b>6</b>	<b>260</b>	<b>100</b>	<b>12</b>	<b>490</b>	<b>100</b>	<b>6</b>	<b>280</b>	<b>100</b>
Hyphal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly Wallace, Laboratory Manager  
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. \*\*\*\* Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/15/2022 12:53 PM

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)





# EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / [miamilab@emsl.com](mailto:miamilab@emsl.com)

EMSL Order: 172205469

Customer ID: AQE63

Customer PO:

Project ID:

**Attention:** Lab Results

AirQuest Environmental, Inc.

6851 Southwest 45th Street

Fort Lauderdale, FL 33314

**Phone:** (954) 792-4549

**Fax:** (954) 792-2221

**Collected Date:** 10/14/2022

**Received Date:** 10/15/2022 07:00 AM

**Analyzed Date:** 10/15/2022

**Project:** 8901 Cypress Lake Dr. Fort Myers, FL 33919 #19571

### Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	172205469-0016 CLMS-16 75 Outdoors-East			172205469-0017 CLMS-17 75 Outdoors-West			172205469-0018 CLMS-18 75 704--Classroom		
Spore Types	Raw Count	Count/M <sup>3</sup>	% of Total	Raw Count	Count/M <sup>3</sup>	% of Total	Raw Count	Count/M <sup>3</sup>	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	2	90	2.4	2	90	8.7	-	-	-
Aspergillus/Penicillium	35	1500	40.7	10	440	42.3	-	-	-
Basidiospores	5	200	5.4	2	90	8.7	-	-	-
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-
Cladosporium	40	1700	46.1	4	200	19.2	-	-	-
Curvularia	1*	10*	0.3	2	90	8.7	1	40	100
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	1	40	3.8	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Beltrania	-	-	-	-	-	-	-	-	-
Cercospora++	2	90	2.4	2	90	8.7	-	-	-
Pyricularia	3	100	2.7	-	-	-	-	-	-
<b>Total Fungi</b>	<b>88</b>	<b>3690</b>	<b>100</b>	<b>23</b>	<b>1040</b>	<b>100</b>	<b>1</b>	<b>40</b>	<b>100</b>
Hyphal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	1	40	-	-	-	-	-	-	-
Pollen	1*	10*	-	1	40	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly Wallace, Laboratory Manager  
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/15/2022 12:53 PM

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)



# EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / [miamilab@emsl.com](mailto:miamilab@emsl.com)

EMSL Order: 172205469

Customer ID: AQE63

Customer PO:

Project ID:

**Attention:** Lab Results

AirQuest Environmental, Inc.

6851 Southwest 45th Street

Fort Lauderdale, FL 33314

**Phone:** (954) 792-4549

**Fax:** (954) 792-2221

**Collected Date:** 10/14/2022

**Received Date:** 10/15/2022 07:00 AM

**Analyzed Date:** 10/15/2022

**Project:** 8901 Cypress Lake Dr. Fort Myers, FL 33919 #19571

### Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	172205469-0019 CLMS-19 75 705--Classroom			172205469-0020 CLMS-20 75 901--Classroom			172205469-0021 CLMS-21 75 905--Classroom		
Spore Types	Raw Count	Count/M <sup>3</sup>	% of Total	Raw Count	Count/M <sup>3</sup>	% of Total	Raw Count	Count/M <sup>3</sup>	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	1	40	28.6	-	-	-	-	-	-
Aspergillus/Penicillium	3	100	71.4	-	-	-	-	-	-
Basidiospores	-	-	-	-	-	-	-	-	-
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	-	-	-	-	-	-
Curvularia	-	-	-	-	-	-	2	90	69.2
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	1	40	30.8
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Beltrania	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	-	-	-	-	-	-
Pyricularia	-	-	-	-	-	-	-	-	-
<b>Total Fungi</b>	<b>4</b>	<b>140</b>	<b>100</b>	<b>-</b>	<b>None Detect</b>	<b>-</b>	<b>3</b>	<b>130</b>	<b>100</b>
Hyphal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly Wallace, Laboratory Manager  
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. \*\*\*\* Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/15/2022 12:53 PM

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)



# EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / [miamilab@emsl.com](mailto:miamilab@emsl.com)

EMSL Order: 172205469

Customer ID: AQE63

Customer PO:

Project ID:

**Attention:** Lab Results

AirQuest Environmental, Inc.

6851 Southwest 45th Street

Fort Lauderdale, FL 33314

**Phone:** (954) 792-4549

**Fax:** (954) 792-2221

**Collected Date:** 10/14/2022

**Received Date:** 10/15/2022 07:00 AM

**Analyzed Date:** 10/15/2022

**Project:** 8901 Cypress Lake Dr. Fort Myers, FL 33919 #19571

### Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	172205469-0022 CLMS-22 75 908--Classroom			172205469-0023 CLMS-23 75 Girl's Locker Room			172205469-0024 CLMS-24 75 Outdoors-South			
	Spore Types	Raw Count	Count/M <sup>3</sup>	% of Total	Raw Count	Count/M <sup>3</sup>	% of Total	Raw Count	Count/M <sup>3</sup>	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	2	90	2.3	3	100	2.9	
Aspergillus/Penicillium	-	-	-	3	100	2.6	-	-	-	
Basidiospores	-	-	-	1	40	1	2	90	2.6	
Bipolaris++	-	-	-	-	-	-	-	-	-	
Chaetomium++	-	-	-	-	-	-	-	-	-	
Cladosporium	-	-	-	81	3500	90.9	68	3000	86.7	
Curvularia	-	-	-	1	40	1	1	40	1.2	
Epicoccum	-	-	-	-	-	-	-	-	-	
Fusarium++	-	-	-	-	-	-	-	-	-	
Ganoderma	-	-	-	1	40	1	2	90	2.6	
Myxomycetes++	-	-	-	-	-	-	1	40	1.2	
Pithomyces++	-	-	-	-	-	-	-	-	-	
Rust	-	-	-	-	-	-	-	-	-	
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-	
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-	
Unidentifiable Spores	-	-	-	-	-	-	-	-	-	
Zygomycetes	-	-	-	-	-	-	-	-	-	
Beltrania	-	-	-	-	-	-	-	-	-	
Cercospora++	-	-	-	1	40	1	3	100	2.9	
Pyricularia	-	-	-	-	-	-	-	-	-	
<b>Total Fungi</b>	-	<b>None Detect</b>	-	<b>90</b>	<b>3850</b>	<b>100</b>	<b>80</b>	<b>3460</b>	<b>100</b>	
Hyphal Fragment	-	-	-	-	-	-	-	-	-	
Insect Fragment	-	-	-	1	40	-	-	-	-	
Pollen	-	-	-	-	-	-	3	100	-	
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-	
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-	
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-	
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-	
Background (1-5)	-	1	-	-	2	-	-	1	-	

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly Wallace, Laboratory Manager  
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. \*\*\*\* Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/15/2022 12:53 PM

For information on the fungi listed in this report, please visit the Resources section at [www.emsl.com](http://www.emsl.com)

172205469

Chain of Custody  
Laboratory Sample Submittal Form

Phone: (954) 792-4549  
Fax: (954) 792-2221  
Toll Free: (877) 247-8146  
Email: labresults@airquestinc.com  
TAT: 3 Hr. ; 6 Hr. ; 24 Hr. ; Other



6851 SW 45th Street  
Fort Lauderdale, Florida 33314

Sample Date: 10-14-22  
Project Number: 19571  
Site Address: 8901 Cypress Lake Dr  
Fort Myers, FL 33919  
Collected By: George Ramundo

Bulk Sample Type	
Code	Description
TL	Tape Lift Sample for Fungi
SW	Swab Sample for Fungi
WP	Wipe Sample for Fungi
BF	Bulk Sample for Fungi
BB	Bulk Sample for E. Coli/Total Coliform
Other	
Other	
Other	

Air Sample Type	
Code	Description
AOC	AirCell Sample for Fungi & Particulate
AS	N6 Sample for Viable Fungi
ASB	N6 Sample for Bacteria
Other	

Item	Code	Sample Number	Description	Location	Volume/Quantity /Area	Comments
1	AOC	CLMS-01	Base line Comparison	OUTDOORS - FRONT	75 Lt.	
2	↓	CLMS-02	Breathing Zone	Main OFFICE - Entrance	↓	
3	↓	CLMS-03	↓	Main OFFICE - REAR	↓	
4	↓	CLMS-04	↓	MEDIA CENTER	↓	
5	↓	CLMS-05	↓	CAFETERIA	↓	
6	↓	CLMS-06	↓	STAFF DINING	↓	
7	↓	CLMS-07	↓	301-CLASSROOM	↓	
8	↓	CLMS-08	↓	406-CLASSROOM	↓	
9	↓	CLMS-09	↓	403-CLASSROOM	↓	
10	↓	CLMS-10	↓	501-CLASSROOM	↓	

Relinquished by: George Ramundo Initials: GR Tracking # \_\_\_\_\_  
 Received by: My Phanel Fedex:   
 Relinquished by: \_\_\_\_\_ Date & Time: 10-14-22 @ 12:00PM  
 Received by: \_\_\_\_\_ Date & Time: 10-15-22 8:00AM  
 Relinquished by: \_\_\_\_\_ Date & Time: \_\_\_\_\_  
 Received by: \_\_\_\_\_ Date & Time: \_\_\_\_\_  
 Hand Couriered

172205469

Chain of Custody  
Laboratory Sample Submittal Form

Phone: (954) 792-4549  
 Fax: (954) 792-2221  
 Toll Free: (877) 247-8146  
 Email: labresults@airquestinc.com  
 TAT: 3 Hr.; 6 Hr.; 24 Hr.; Other



6851 SW 45th Street  
 Fort Lauderdale, Florida 33314

Sample Date: 10-14-22  
 Project Number: 19571  
 Site Address: 8901 Cypress Lake Dr.  
 Fort Myers, FL 33919  
 Collected By: George Ramundo

Bulk Sample Type	
Code	Description
TL	Tape Lift Sample for Fungi
SW	Swab Sample for Fungi
WP	Wipe Sample for Fungi
BF	Bulk Sample for Fungi
BB	Bulk Sample for E. Coli/Total Coliform
Other	
Other	

Air Sample Type	
Code	Description
AOC	Air-Cell Sample for Fungi & Particulate
AS	N6 Sample for Viable Fungi
ASB	N6 Sample for Bacteria
Other	

Item	Code	Sample Number	Description	Location	Volume/Quantity /Area	Comments
1	AOC	CLMS- 11	Breathing Zone	504- Classroom	75 Lt.	
2	↓	CLMS- 12	↓	601- classroom	↓	
3	↓	CLMS- 13	↓	803- classroom	↓	
4	↓	CLMS- 14	↓	811- classroom	↓	
5	↓	CLMS- 15	↓	814- classroom	↓	
6	↓	CLMS- 16	Baseline Comparison	OUTDOORS - EAST	↓	
7	↓	CLMS- 17	Baseline Comparison	OUTDOORS - WEST	↓	
8	↓	CLMS- 18	Breathing Zone	704- Classroom	↓	
9	↓	CLMS- 19	↓	705 classroom	↓	
10	↓	CLMS- 20	↓	901- classroom	↓	

Relinquished by: George Ramundo Initial GR Tracking # \_\_\_\_\_  
 Received by: Meg Havel Fedex:  Hand Courtered   
 Relinquished by: \_\_\_\_\_ Date & Time: 10-14-22 @ 12:00PM  
 Received by: \_\_\_\_\_ Date & Time: 10-15-22 @ 8 AM

172205469

Chain of Custody  
Laboratory Sample Submittal Form

Phone: (954) 792-4549  
 Fax: (954) 792-2221  
 Toll Free: (877) 247-8146  
 Email: labresults@airquestinc.com  
 TAT: 3 Hr. ; 6 Hr. ; 24 Hr. ; Other



6851 SW 45th Street  
 Fort Lauderdale, Florida 33314

Sample Date: 10-14-22  
 Project Number: 19571  
 Site Address: 8701 Cypress Lake Dr.  
 Fort Myers Fl. 33919  
 Collected By: GEORGE PERIMUNDO

Bulk Sample Type	
Code	Description
TL	Tape Lift Sample for Fungi
SW	Swab Sample for Fungi
WP	Wipe Sample for Fungi
BF	Bulk Sample for Fungi
BB	Bulk Sample for E. Coli/Total Coliform
Other	
Other	
Other	

Air Sample Type	
Code	Description
AOC	Air/OCell Sample for Fungi & Particulate
AS	N6 Sample for Viable Fungi
ASB	N6 Sample for Bacteria
Other	

Item	Code	Sample Number	Description	Location	Volume/Quantity /Area	Comments
1	AOC	CLMS - 21	Breathing Zone	905-CLASSROOM	75 LT.	
2	↓	CLMS - 22	↓	908-CLASSROOM	↓	
3	↓	CLMS - 23	↓	Girl's Locker Room	↓	
4	↓	CLMS - 24	Baseline Comparison	Outdoors - South	↓	
5						
6						
7						
8						
9						
10						

Relinquished by: GEORGE Initial: GP Tracking # \_\_\_\_\_  
 Received by: Myr Hamel Fedex:   
 Relinquished by: \_\_\_\_\_ Date & Time: 10-14-22 @ 12:00 PM  
 Received by: \_\_\_\_\_ Date & Time: 10-15-22 @ 8 AM  
 Relinquished by: \_\_\_\_\_ Date & Time: \_\_\_\_\_  
 Received by: \_\_\_\_\_ Date & Time: \_\_\_\_\_  
 Hand Courtered



CLMS

SCHOOL:

Cypress Lake Middle School

Date: 10/14/22

Room / Area:

1st office

Temp.	rH%	Dew Point
76	59	60

PRV NOTES

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- |            |                                |                                  |                              |
|------------|--------------------------------|----------------------------------|------------------------------|
| North Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| East Wall  | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| South Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| West Wall  | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |

Flooring:

- |   |   |
|---|---|
| <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Wet            |
| <input type="checkbox"/> Dirty            | <input checked="" type="checkbox"/> Dry |
| <input type="checkbox"/> VMG              |   |

Air Sampling:

- YES  NO

AOC

Date: \_\_\_/\_\_\_/\_\_\_

NOTES:

114 - 1 stained ACT, dry

---



---



---



---



Date: 10/14/22

SCHOOL: CLMS

Room / Area: Media Center

Temp.	rH%	Dew Point
72	74	64

### PRV NOTES

#### Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

#### Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

#### Walls:

- |            |   |   |                              |
|------------|---|---|------------------------------|
| North Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained            | <input type="checkbox"/> VMG |
| East Wall  | <input type="checkbox"/> Clean            | <input checked="" type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| South Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained            | <input type="checkbox"/> VMG |
| West Wall  | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained            | <input type="checkbox"/> VMG |

#### Flooring:

- |   |   |
|---|---|
| <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Wet            |
| <input type="checkbox"/> Dirty            | <input checked="" type="checkbox"/> Dry |
| <input type="checkbox"/> VMG              |   |

#### Air Sampling:

- YES  NO
- AOC
- Date: \_\_\_/\_\_\_/\_\_\_

#### NOTES:

- Water staining on concrete wall near CCTV storage
- 01-042B: " "
- Speech / Listening: NO ACCESS

Date: 10/14/22

SCHOOL: CLMS  
Room / Area: 2-Cafeteria

Temp.	rH%	Dew Point
73	67	61

### P R V NOTES

#### Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

#### Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

#### Walls:

- |            |   |                                  |                              |
|------------|---|----------------------------------|------------------------------|
| North Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| East Wall  | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| South Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| West Wall  | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |

#### Flooring:

- |   |   |
|---|---|
| <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Wet            |
| <input type="checkbox"/> Dirty            | <input checked="" type="checkbox"/> Dry |
| <input type="checkbox"/> VMG              |   |

#### Air Sampling:

- YES  NO

AOC

Date: \_\_\_/\_\_\_/\_\_\_

#### NOTES:

1 stained ACT, dry  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

SCHOOL:

CLMS

Date: 10/14/22

Room / Area:

3

Temp.	rH%	Dew Point
80	69	68

### PRV NOTES

#### Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

#### Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

#### Walls:

- |            |   |                                  |                              |
|------------|---|----------------------------------|------------------------------|
| North Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| East Wall  | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| South Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| West Wall  | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |

#### Flooring:

- Clean
- Dirty
- VMG
- Wet
- Dry

#### Air Sampling:

- YES
- NO
- AOC
- Date: \_\_\_/\_\_\_/\_\_\_

#### NOTES:

3-001C: stained fiberglass roof deck, dry

---



---



---

Date: 10/14/22

SCHOOL: CLMS  
Room / Area: 4

Temp.	rH%	Dew Point
78	49	56

### PRV NOTES

#### Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

#### Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

#### Walls:

- |            |   |                                  |                              |
|------------|---|----------------------------------|------------------------------|
| North Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| East Wall  | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| South Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| West Wall  | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |

#### Flooring:

- |   |   |
|---|---|
| <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Wet            |
| <input type="checkbox"/> Dirty            | <input checked="" type="checkbox"/> Dry |
| <input type="checkbox"/> VMG              |   |

#### Air Sampling:

- YES  NO

AOC

Date: \_\_\_/\_\_\_/\_\_\_

#### NOTES:

---

---

---

---

Date: 10/14/22

SCHOOL: CLMS

Room / Area: S

Temp.	rH%	Dew Point
78	51	58

### PRV NOTES

#### Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

#### Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

#### Walls:

- |            |                                |                                  |                              |
|------------|--------------------------------|----------------------------------|------------------------------|
| North Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| East Wall  | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| South Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| West Wall  | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |

#### Flooring:

- |   |   |
|---|---|
| <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Wet            |
| <input type="checkbox"/> Dirty            | <input checked="" type="checkbox"/> Dry |
| <input type="checkbox"/> VMG              |   |

#### Air Sampling:

- YES  NO

AOC

Date: \_/\_/\_

#### NOTES:

501A - 1 stained ACT, dry

501 - "

519 - "

506 - 2 "

Date: 10/14/20

SCHOOL: CLMS

Room / Area: 6

Temp.	rH%	Dew Point
72	45	49

### P R V NOTES

#### Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

#### Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

#### Walls:

- |            |                                |                                  |                              |
|------------|--------------------------------|----------------------------------|------------------------------|
| North Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| East Wall  | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| South Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| West Wall  | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |

#### Flooring:

- Clean
- Dirty
- VMG
- Wet
- Dry

#### Air Sampling:

- YES
- NO

A O C

Date: \_\_\_/\_\_\_/\_\_\_

#### NOTES:

601-D: Wet ACT & 5 SF wet carpet

---



---



---

Date: 10/14/22

SCHOOL: CLMS

Room / Area: 7

Temp.	rH%	Dew Point
76	26	39

### P R V NOTES

#### Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

#### Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

#### Walls:

- North Wall  Clean  Stained  VMG
- East Wall  Clean  Stained  VMG
- South Wall  Clean  Stained  VMG
- West Wall  Clean  Stained  VMG

#### Flooring:

- Clean
- Dirty
- VMG

Wet

Dry

#### Air Sampling:

- YES
- NO

A O C

Date: \_\_\_/\_\_\_/\_\_\_

#### NOTES:

---



---



---



---

Date: 10/14/22

SCHOOL: CLMS

Room / Area: 8

Temp.	rH%	Dew Point
77	46	54

### PRV NOTES

#### Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

#### Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

#### Walls:

- |            |                                |                                  |                              |
|------------|--------------------------------|----------------------------------|------------------------------|
| North Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| East Wall  | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| South Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| West Wall  | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |

#### Flooring:

- |   |   |
|---|---|
| <input checked="" type="checkbox"/> Clean | <input checked="" type="checkbox"/> Wet |
| <input type="checkbox"/> Dirty            | <input type="checkbox"/> Dry            |
| <input type="checkbox"/> VMG              |   |

#### Air Sampling:

- YES  NO

AOC

Date: \_\_\_/\_\_\_/\_\_\_

#### NOTES:

808B - wet carpet underneath fridge

804 - Stained ACT, dry (1) (Kara Vereen)

---



---



---



Date: 10/14/

SCHOOL: CLMS

Room / Area: 9

Temp.	rH%	Dew Point
74	50	54

### P R V NOTES

#### Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

#### Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

#### Walls:

- North Wall  Clean  Stained  VMG
- East Wall  Clean  Stained  VMG
- South Wall  Clean  Stained  VMG
- West Wall  Clean  Stained  VMG

#### Flooring:

- Clean  Wet
- Dirty  Dry
- VMG

#### Air Sampling:

- YES  NO

AOC

Date: \_/\_/\_

#### NOTES:

905C: 1 stained ACT, dry

---

907: 1 "

---

908B: 1 "

---

906: 3 "

---

904: 2 "

SCHOOL:

CLMS

Date: 10/14/22

Room / Area:

Gym / Locker Rooms

Temp.	rH%	Dew Point
89	50	70

### PRV NOTES

#### Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

#### Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

#### Walls:

- |            |   |   |                              |
|------------|---|---|------------------------------|
| North Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained            | <input type="checkbox"/> VMG |
| East Wall  | <input type="checkbox"/> Clean            | <input checked="" type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| South Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained            | <input type="checkbox"/> VMG |
| West Wall  | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained            | <input type="checkbox"/> VMG |

#### Flooring:

- Clean
- Dirty
- VMG
- Wet
- Dry

#### Air Sampling:

- YES
- NO

AOC

Date: \_\_\_/\_\_\_/\_\_\_

#### NOTES:

10020: 5 ACT stained, dry

Boys locker room office: 3 ACT, stained, ~~stained~~

1001E: Water-damaged concrete (NET) on wall

Gym: 500 SF water-damaged wood flooring, wet  
Water-damaged/wet wood cabinets