



October 15, 2022

Matt Odachowski
Royal Plus
201 Belt Street
Snow Hill, MD 21863

**RE: Skyline Elementary School
Executive Summary for School Clearance and Reoccupation
Post Restoration / Remediation Verification (PRV)**

Mr. Odachowski:

Industrial Hygiene Consulting, Corp. (IHC) is pleased to provide you this executive summary letter of substantial completion and health and safety clearance for the Hurricane Ian restoration and remediation related work performed at the Skyline Elementary School campus located at 620 SW 19th Street in Cape Coral, Florida. The primary health and safety clearance was performed on October 14, 2022. The post restoration inspection and clearance related work performed by IHC included the following:

- Development of the building restoration / remediation specification and standard operating procedures for the Hurricane Ian recovery effort.
- Perform ongoing monitoring of moisture conditions within the interior of the buildings to ensure the atmospheric conditions were stabilized and controlled to prevent fungal growth throughout the interior of the buildings.
- Perform visual inspection and assessment of the interior of each room within each building to ensure the indoor environmental conditions are visually clean, free of water related odors, free of significant visual water stains, physical water damage and visual fungal growth.
- Collection of air quality bioaerosol samples to verify the indoor environmental conditions are acceptable for the health and safety of all occupants (students and staff) returning to each building.

Conclusions / Summary of Findings

1. The restoration of the previously water impacted and restored portions of the property has met the outlined criteria for acceptance and PASSES the post restoration / remediation verification clearance.
2. The indoor environment of the school buildings are visually clean, free from water related odors, visually free of significant water stains and free from visual fungal growth.
3. The results of the air quality bioaerosol sampling indicated low or normal total airborne fungal counts relative to the outdoor control samples. Additionally, the fungal organism orientation of indoor air genera to the outdoor control sample air genera are similar and there is no significant dominance indoors of undesirable fungal organisms or hydrophilic fungal organisms, such as *Stachybotrys* and *Chaetomium*. See the attached laboratory data as verification of acceptable conditions.
 - The exceptions to this where the fungal air counts were elevated and not consistent with passing criteria were in the media center, cafeteria, kitchen and classroom 043.

Recommendations (Remaining Action Items to Complete)

- A. Reclean the rooms and areas that did not pass air quality testing (media center, cafeteria, kitchen and classroom 043). Once recleaned the PRV retesting will be performed.
- B. Continue to manage water intrusion and ceiling tile replacement as necessary.

Standard of Care

Information provided in this document is based upon current and generally recognized scientific and technical understanding of the issues presented. In addition, some causes may be masked or hidden by conditions or activities in the building. As a result, the conclusions and recommendations do not guarantee that all factors have been identified and that all issues will be resolved if the recommendations are implemented. The conclusions and recommendations made in this document are our professional opinion and are based on the observations made and conditions present at the time of the investigation, discussions with individuals involved, and the results of tests and/or measurements performed. Following or implementing the recommendations does not provide complete protection from future building occupant irritation or possible health consequences that may be caused by indoor environmental conditions. No warranty is implied or intended. The report prepared by Consultant and all written documentation created by Consultant are Consultant's work product and protect by US Copyright law (17 USC 101 et seq). Provided Owner is not in material breach of this Agreement and has paid all amounts due to Owner hereunder, Consultant grants to Owner a perpetual license to use the report.

If you have any additional questions or concerns, please do not hesitate to contact me directly at 866-989-5567, ext 1.

Sincerely,

A handwritten signature in black ink that reads "Slade K. Smith". The signature is written in a cursive style and is positioned above the typed name.

Slade K. Smith, RPIH, AIEH, IICRC AMRT Instructor, IICRC Master Restorer
Industrial Hygiene Consulting, Corp. 866-989-5567



EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / miamilab@emsl.com

EMSL Order: 172205470

Customer ID: AQE63

Customer PO:

Project ID:

Attention: Lab Results

AirQuest Environmental, Inc.

6851 Southwest 45th Street

Fort Lauderdale, FL 33314

Phone: (954) 792-4549

Fax: (954) 792-2221

Collected Date: 10/14/2022

Received Date: 10/15/2022 07:16 AM

Analyzed Date: 10/15/2022

Project: 19751-Skyline Elem. School 620 SW 19th St. Cape Coral, FL 33991

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	172205470-0001 SES-01 75 Outdoors-West			172205470-0002 SES-02 75 Outdoors-North			172205470-0003 SES-03 75 BLDG.4-Media Center			
	Spore Types	Raw Count	Count/M³	% of Total	Raw Count	Count/M³	% of Total	Raw Count	Count/M³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-	-
Ascospores	4	200	2.7	-	-	-	-	-	-	-
Aspergillus/Penicillium	5	200	2.7	71	3100	45.5	76	3300	97.6	
Basidiospores	1	40	0.5	4	200	2.9	-	-	-	-
Bipolaris++	-	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-	-
Cladosporium	154	6720	89.1	57	2500	36.7	-	-	-	-
Curvularia	6	300	4	6	300	4.4	1	40	1.2	
Epicoccum	-	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-	-
Ganoderma	1	40	0.5	1	40	0.6	-	-	-	-
Myxomycetes++	-	-	-	1	40	0.6	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	4	200	2.9	-	-	-	-
Cercospora++	1	40	0.5	7	300	4.4	-	-	-	-
Nigrospora	-	-	-	-	-	-	-	-	-	-
Oidium++	-	-	-	2	90	1.3	-	-	-	-
Pestalotia++	-	-	-	-	-	-	-	-	-	-
Pyricularia	-	-	-	1	40	0.6	1	40	1.2	
Total Fungi	172	7540	100	154	6810	100	78	3380	100	
Hyphal Fragment	-	-	-	1	40	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-	-
Background (1-5)	-	1	-	-	1	-	-	1	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly Wallace, Laboratory Manager
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. **** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/15/2022 12:51 PM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / miamilab@emsl.com

EMSL Order: 172205470

Customer ID: AQE63

Customer PO:

Project ID:

Attention: Lab Results

AirQuest Environmental, Inc.
6851 Southwest 45th Street
Fort Lauderdale, FL 33314

Phone: (954) 792-4549

Fax: (954) 792-2221

Collected Date: 10/14/2022

Received Date: 10/15/2022 07:16 AM

Analyzed Date: 10/15/2022

Project: 19751-Skyline Elem. School 620 SW 19th St. Cape Coral, FL 33991

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	172205470-0004 SES-04 75 BLDG.4-Media Center			172205470-0005 SES-05 75 Cafeteria			172205470-0006 SES-06 75 Kitchen			
	Spore Types	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	-	-	-	-
Aspergillus/Penicillium	16	700	61.4	53	2300	53.7	-	-	-	-
Basidiospores	-	-	-	-	-	-	-	-	-	-
Bipolaris++	-	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-	-
Cladosporium	9	400	35.1	44	1900	44.4	47	2100	92.5	-
Curvularia	-	-	-	1	40	0.9	2	90	4	-
Epicoccum	-	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	1	40	1.8	-
Myxomycetes++	-	-	-	-	-	-	-	-	-	-
Pithomyces++	1	40	3.5	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	1	40	0.9	-	-	-	-
Nigrospora	-	-	-	-	-	-	-	-	-	-
Oidium++	-	-	-	-	-	-	-	-	-	-
Pestalotia++	-	-	-	-	-	-	1	40	1.8	-
Pyricularia	-	-	-	-	-	-	-	-	-	-
Total Fungi	26	1140	100	99	4280	100	51	2270	100	
Hyphal Fragment	-	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-	-
Background (1-5)	-	1	-	-	2	-	-	2	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly Wallace, Laboratory Manager
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. **** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/15/2022 12:51 PM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / miamilab@emsl.com

EMSL Order: 172205470

Customer ID: AQE63

Customer PO:

Project ID:

Attention: Lab Results

AirQuest Environmental, Inc.
6851 Southwest 45th Street
Fort Lauderdale, FL 33314

Phone: (954) 792-4549

Fax: (954) 792-2221

Collected Date: 10/14/2022

Received Date: 10/15/2022 07:16 AM

Analyzed Date: 10/15/2022

Project: 19751-Skyline Elem. School 620 SW 19th St. Cape Coral, FL 33991

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	172205470-0007 SES-07 75 06-032 Art			172205470-0008 SES-08 75 06-034- Resource			172205470-0009 SES-09 75 05-048- Classroom			
	Spore Types	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³	% of Total
Alternaria (Ullocladium)	-	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	-	-	-	-
Aspergillus/Penicillium	-	-	-	6	300	75	-	-	-	-
Basidiospores	-	-	-	-	-	-	1*	10*	1.1	-
Bipolaris++	-	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-	-
Cladosporium	6	300	100	3	100	25	20	870	94.6	-
Curvularia	-	-	-	-	-	-	1	40	4.3	-
Epicoccum	-	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	-	-	-	-	-	-	-
Nigrospora	-	-	-	-	-	-	-	-	-	-
Oidium++	-	-	-	-	-	-	-	-	-	-
Pestalotia++	-	-	-	-	-	-	-	-	-	-
Pyricularia	-	-	-	-	-	-	-	-	-	-
Total Fungi	6	300	100	9	400	100	22	920	100	
Hyphal Fragment	-	-	-	1	40	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-	-
Background (1-5)	-	1	-	-	1	-	-	1	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly Wallace, Laboratory Manager
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. **** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/15/2022 12:51 PM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / miamilab@emsl.com

EMSL Order: 172205470

Customer ID: AQE63

Customer PO:

Project ID:

Attention: Lab Results

AirQuest Environmental, Inc.

6851 Southwest 45th Street

Fort Lauderdale, FL 33314

Phone: (954) 792-4549

Fax: (954) 792-2221

Collected Date: 10/14/2022

Received Date: 10/15/2022 07:16 AM

Analyzed Date: 10/15/2022

Project: 19751-Skyline Elem. School 620 SW 19th St. Cape Coral, FL 33991

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	172205470-0010 SES-10 75 05-038- Classroom			172205470-0011 SES-11 75 05-043- Classroom			172205470-0012 SES-12 75 05-054- Classroom			
	Spore Types	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	2	90	4.3	-	-	-	-
Aspergillus/Penicillium	-	-	-	28	1200	57.4	-	-	-	-
Basidiospores	-	-	-	-	-	-	1	40	1.8	-
Bipolaris++	-	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-	-
Cladosporium	9	400	90.9	18	790	37.8	48	2100	92.5	-
Curvularia	1	40	9.1	1*	10*	0.5	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	1	40	1.8	-
Myxomycetes++	-	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	-	-	-	2	90	4	-
Nigrospora	-	-	-	-	-	-	-	-	-	-
Oidium++	-	-	-	-	-	-	-	-	-	-
Pestalotia++	-	-	-	-	-	-	-	-	-	-
Pyricularia	-	-	-	-	-	-	-	-	-	-
Total Fungi	10	440	100	49	2090	100	52	2270	100	
Hyphal Fragment	-	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-	-
Background (1-5)	-	1	-	-	1	-	-	1	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly Wallace, Laboratory Manager
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. **** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/15/2022 12:51 PM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / miamilab@emsl.com

EMSL Order: 172205470

Customer ID: AQE63

Customer PO:

Project ID:

Attention: Lab Results

AirQuest Environmental, Inc.

6851 Southwest 45th Street

Fort Lauderdale, FL 33314

Phone: (954) 792-4549

Fax: (954) 792-2221

Collected Date: 10/14/2022

Received Date: 10/15/2022 07:16 AM

Analyzed Date: 10/15/2022

Project: 19751-Skyline Elem. School 620 SW 19th St. Cape Coral, FL 33991

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	172205470-0013 SES-13 75 05-055- Classroom			172205470-0014 SES-14 75 05-056- Teacher's Lounge			172205470-0015 SES-15 75 05-009- Classroom			
	Spore Types	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	-	-	-	-
Aspergillus/Penicillium	-	-	-	-	-	-	-	-	-	-
Basidiospores	-	-	-	-	-	-	1	40	2.7	-
Bipolaris++	-	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-	-
Cladosporium	3	100	43.5	35	1500	83.3	7	300	20.4	-
Curvularia	2	90	39.1	-	-	-	19	830	56.5	-
Epicoccum	-	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-	-
Myxomycetes++	1	40	17.4	7	300	16.7	5	200	13.6	-
Pithomyces++	-	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	-	-	-	3	100	6.8	-
Nigrospora	-	-	-	-	-	-	-	-	-	-
Oidium++	-	-	-	-	-	-	-	-	-	-
Pestalotia++	-	-	-	-	-	-	-	-	-	-
Pyricularia	-	-	-	-	-	-	-	-	-	-
Total Fungi	6	230	100	42	1800	100	35	1470	100	-
Hyphal Fragment	-	-	-	-	-	-	1	40	-	-
Insect Fragment	1	40	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-	-
Background (1-5)	-	1	-	-	1	-	-	1	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly Wallace, Laboratory Manager
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. **** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/15/2022 12:51 PM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / miamilab@emsl.com

EMSL Order: 172205470

Customer ID: AQE63

Customer PO:

Project ID:

Attention: Lab Results

AirQuest Environmental, Inc.
6851 Southwest 45th Street
Fort Lauderdale, FL 33314

Phone: (954) 792-4549

Fax: (954) 792-2221

Collected Date: 10/14/2022

Received Date: 10/15/2022 07:16 AM

Analyzed Date: 10/15/2022

Project: 19751-Skyline Elem. School 620 SW 19th St. Cape Coral, FL 33991

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	172205470-0016 SES-16 75 07-014- Classroom			172205470-0017 SES-17 75 07-005- Classroom			172205470-0018 SES-18 75 07-010- Classroom			
	Spore Types	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	-	-	-	-
Aspergillus/Penicillium	-	-	-	-	-	-	-	-	-	-
Basidiospores	1	40	100	-	-	-	-	-	-	-
Bipolaris++	-	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	2	90	50	-	-	-	-
Curvularia	-	-	-	2	90	50	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	-	-	-	-	-	-	-
Nigrospora	-	-	-	-	-	-	-	-	-	-
Oidium++	-	-	-	-	-	-	-	-	-	-
Pestalotia++	-	-	-	-	-	-	-	-	-	-
Pyricularia	-	-	-	-	-	-	-	-	-	-
Total Fungi	1	40	100	4	180	100	-	None Detect	-	-
Hyphal Fragment	2	90	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-	-
Background (1-5)	-	1	-	-	1	-	-	1	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly Wallace, Laboratory Manager
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. **** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/15/2022 12:51 PM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / miamilab@emsl.com

EMSL Order: 172205470

Customer ID: AQE63

Customer PO:

Project ID:

Attention: Lab Results

AirQuest Environmental, Inc.
6851 Southwest 45th Street
Fort Lauderdale, FL 33314

Phone: (954) 792-4549

Fax: (954) 792-2221

Collected Date: 10/14/2022

Received Date: 10/15/2022 07:16 AM

Analyzed Date: 10/15/2022

Project: 19751-Skyline Elem. School 620 SW 19th St. Cape Coral, FL 33991

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	172205470-0019 SES-19 75 99-2187-Portable			172205470-0020 SES-20 75 Outdoors-West			172205470-0021 SES-21 75 14-211 Resource Planning		
	Spore Types	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³
Alternaria (Ulocladium)	-	-	-	2*	30*	1.5	-	-	-
Ascospores	-	-	-	-	-	-	1	40	14.3
Aspergillus/Penicillium	1*	10*	5.6	-	-	-	-	-	-
Basidiospores	1	40	22.2	1	40	2	-	-	-
Bipolaris++	-	-	-	1*	10*	0.5	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-
Cladosporium	2	90	50	35	1500	73.9	5	200	71.4
Curvularia	1	40	22.2	5	200	9.9	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	4	200	9.9	1	40	14.3
Nigrospora	-	-	-	1*	10*	0.5	-	-	-
Oidium++	-	-	-	-	-	-	-	-	-
Pestalotia++	-	-	-	-	-	-	-	-	-
Pyricularia	-	-	-	1	40	2	-	-	-
Total Fungi	5	180	100	50	2030	100	7	280	100
Hyphal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly Wallace, Laboratory Manager
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. **** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/15/2022 12:51 PM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / miamilab@emsl.com

EMSL Order: 172205470

Customer ID: AQE63

Customer PO:

Project ID:

Attention: Lab Results

AirQuest Environmental, Inc.
6851 Southwest 45th Street
Fort Lauderdale, FL 33314

Phone: (954) 792-4549

Fax: (954) 792-2221

Collected Date: 10/14/2022

Received Date: 10/15/2022 07:16 AM

Analyzed Date: 10/15/2022

Project: 19751-Skyline Elem. School 620 SW 19th St. Cape Coral, FL 33991

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	172205470-0022 SES-22 75 14-207- Classroom			172205470-0023 SES-23 75 14-202- Classroom			172205470-0024 SES-24 75 14-009- Classroom			
	Spore Types	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	-	-	-	-
Aspergillus/Penicillium	7	300	100	-	-	-	-	-	-	-
Basidiospores	-	-	-	-	-	-	-	-	-	-
Bipolaris++	-	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	-	-	-	1	40	50	-
Curvularia	-	-	-	-	-	-	1	40	50	-
Epicoccum	-	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	-	-	-	-	-	-	-
Nigrospora	-	-	-	-	-	-	-	-	-	-
Oidium++	-	-	-	-	-	-	-	-	-	-
Pestalotia++	-	-	-	-	-	-	-	-	-	-
Pyricularia	-	-	-	-	-	-	-	-	-	-
Total Fungi	7	300	100	-	None Detect	-	2	80	100	-
Hyphal Fragment	-	-	-	-	-	-	1	40	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-	-
Background (1-5)	-	1	-	-	1	-	-	1	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly Wallace, Laboratory Manager
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. **** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/15/2022 12:51 PM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / miamilab@emsl.com

EMSL Order: 172205470

Customer ID: AQE63

Customer PO:

Project ID:

Attention: Lab Results

AirQuest Environmental, Inc.
6851 Southwest 45th Street
Fort Lauderdale, FL 33314

Phone: (954) 792-4549

Fax: (954) 792-2221

Collected Date: 10/14/2022

Received Date: 10/15/2022 07:16 AM

Analyzed Date: 10/15/2022

Project: 19751-Skyline Elem. School 620 SW 19th St. Cape Coral, FL 33991

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	172205470-0025 SES-25 75 14-006- Classroom			172205470-0026 SES-26 75 13-209- Classroom			172205470-0027 SES-27 75 13-208- Classroom			
	Spore Types	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	-	-	-	-
Aspergillus/Penicillium	-	-	-	-	-	-	-	-	-	-
Basidiospores	-	-	-	-	-	-	-	-	-	-
Bipolaris++	-	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	-	-	-	1	40	100	-
Curvularia	-	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	-	-	-	-	-	-	-
Nigrospora	-	-	-	-	-	-	-	-	-	-
Oidium++	-	-	-	-	-	-	-	-	-	-
Pestalotia++	-	-	-	-	-	-	-	-	-	-
Pyricularia	-	-	-	-	-	-	-	-	-	-
Total Fungi	-	None Detect	-	-	None Detect	-	1	40	100	-
Hyphal Fragment	-	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-	-
Background (1-5)	-	1	-	-	1	-	-	1	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly Wallace, Laboratory Manager
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. **** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/15/2022 12:51 PM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / miamilab@emsl.com

EMSL Order: 172205470
Customer ID: AQE63
Customer PO:
Project ID:

Attention: Lab Results AirQuest Environmental, Inc. 6851 Southwest 45th Street Fort Lauderdale, FL 33314	Phone: (954) 792-4549 Fax: (954) 792-2221 Collected Date: 10/14/2022 Received Date: 10/15/2022 07:16 AM Analyzed Date: 10/15/2022
Project: 19751-Skyline Elem. School 620 SW 19th St. Cape Coral, FL 33991	

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	172205470-0028 SES-28 75 13-204- Classroom			172205470-0029 SES-29 75 13-009- Classroom			172205470-0030 SES-30 75 13-003- Classroom			
	Spore Types	Raw Count	Count/M³	% of Total	Raw Count	Count/M³	% of Total	Raw Count	Count/M³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	-	-	-	-
Aspergillus/Penicillium	-	-	-	3	100	29.4	2	90	31	
Basidiospores	-	-	-	-	-	-	-	-	-	-
Bipolaris++	-	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	5	200	58.8	4	200	69	
Curvularia	-	-	-	1	40	11.8	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	-	-	-	-	-	-	-
Nigrospora	-	-	-	-	-	-	-	-	-	-
Oidium++	-	-	-	-	-	-	-	-	-	-
Pestalotia++	-	-	-	-	-	-	-	-	-	-
Pyricularia	-	-	-	-	-	-	-	-	-	-
Total Fungi	-	None Detect	-	9	340	100	6	290	100	
Hyphal Fragment	-	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-	-
Background (1-5)	-	1	-	-	1	-	-	1	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly A. Wallace

 Kimberly Wallace, Laboratory Manager
 or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. **** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/15/2022 12:51 PM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / miamilab@emsl.com

EMSL Order: 172205470

Customer ID: AQE63

Customer PO:

Project ID:

Attention: Lab Results

AirQuest Environmental, Inc.

6851 Southwest 45th Street

Fort Lauderdale, FL 33314

Phone: (954) 792-4549

Fax: (954) 792-2221

Collected Date: 10/14/2022

Received Date: 10/15/2022 07:16 AM

Analyzed Date: 10/15/2022

Project: 19751-Skyline Elem. School 620 SW 19th St. Cape Coral, FL 33991

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	172205470-0031 SES-31 75 13-006- Classroom			172205470-0032 SES-32 75 08-016- Classroom			172205470-0033 SES-33 75 08-020- Classroom			
	Spore Types	Raw Count	Count/M³	% of Total	Raw Count	Count/M³	% of Total	Raw Count	Count/M³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	-	-	-	-
Aspergillus/Penicillium	2	90	50	-	-	-	10	440	44	-
Basidiospores	-	-	-	-	-	-	-	-	-	-
Bipolaris++	-	-	-	-	-	-	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	2	90	69.2	12	520	52	-
Curvularia	2	90	50	1	40	30.8	1	40	4	-
Epicoccum	-	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	-	-	-	-	-	-	-
Nigrospora	-	-	-	-	-	-	-	-	-	-
Oidium++	-	-	-	-	-	-	-	-	-	-
Pestalotia++	-	-	-	-	-	-	-	-	-	-
Pyricularia	-	-	-	-	-	-	-	-	-	-
Total Fungi	4	180	100	3	130	100	23	1000	100	
Hyphal Fragment	1	40	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-	-
Background (1-5)	-	1	-	-	1	-	-	1	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly Wallace, Laboratory Manager
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. **** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/15/2022 12:51 PM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / miamilab@emsl.com

EMSL Order: 172205470

Customer ID: AQE63

Customer PO:

Project ID:

Attention: Lab Results

AirQuest Environmental, Inc.
6851 Southwest 45th Street
Fort Lauderdale, FL 33314

Phone: (954) 792-4549

Fax: (954) 792-2221

Collected Date: 10/14/2022

Received Date: 10/15/2022 07:16 AM

Analyzed Date: 10/15/2022

Project: 19751-Skyline Elem. School 620 SW 19th St. Cape Coral, FL 33991

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number: Client Sample ID: Volume (L): Sample Location:	172205470-0034 SES-34 75 09-023- Classroom			172205470-0035 SES-35 75 09-027- Classroom			172205470-0036 SES-36 75 065-Main Office			
	Spore Types	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³	% of Total	Raw Count	Count/M ³	% of Total
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	-	-	-	-	-	-	-
Aspergillus/Penicillium	-	-	-	6	300	41.7	-	-	-	-
Basidiospores	-	-	-	-	-	-	-	-	-	-
Bipolaris++	-	-	-	1	40	5.6	-	-	-	-
Chaetomium++	-	-	-	-	-	-	-	-	-	-
Cladosporium	2	90	52.9	8	300	41.7	-	-	-	-
Curvularia	1	40	23.5	1	40	5.6	1	40	100	-
Epicoccum	-	-	-	-	-	-	-	-	-	-
Fusarium++	-	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-	-	-	-
Pithomyces++	1	40	23.5	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	1	40	5.6	-	-	-	-
Cercospora++	-	-	-	-	-	-	-	-	-	-
Nigrospora	-	-	-	-	-	-	-	-	-	-
Oidium++	-	-	-	-	-	-	-	-	-	-
Pestalotia++	-	-	-	-	-	-	-	-	-	-
Pyricularia	-	-	-	-	-	-	-	-	-	-
Total Fungi	4	170	100	17	720	100	1	40	100	-
Hyphal Fragment	-	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-	-
Background (1-5)	-	1	-	-	2	-	-	2	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly Wallace, Laboratory Manager
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. **** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/15/2022 12:51 PM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com



EMSL Analytical, Inc.

19501 NE 10th Ave. Bay A N. Miami Beach, FL 33179

Tel/Fax: (305) 650-0577 / (305) 650-0578

<http://www.EMSL.com> / miamilab@emsl.com

EMSL Order: 172205470

Customer ID: AQE63

Customer PO:

Project ID:

Attention: Lab Results

AirQuest Environmental, Inc.

6851 Southwest 45th Street

Fort Lauderdale, FL 33314

Phone: (954) 792-4549

Fax: (954) 792-2221

Collected Date: 10/14/2022

Received Date: 10/15/2022 07:16 AM

Analyzed Date: 10/15/2022

Project: 19751-Skyline Elem. School 620 SW 19th St. Cape Coral,FL.33991

Test Report: Air-O-Cell™ Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	172205470-0037		
Client Sample ID:	SES-37		
Volume (L):	75		
Sample Location:	065-Main Office		
Spore Types	Raw Count	Count/M³	% of Total
Alternaria (Ullocladium)	-	-	-
Ascospores	-	-	-
Aspergillus/Penicillium	-	-	-
Basidiospores	-	-	-
Bipolaris++	-	-	-
Chaetomium++	-	-	-
Cladosporium	-	-	-
Curvularia	-	-	-
Epicoccum	-	-	-
Fusarium++	-	-	-
Ganoderma	-	-	-
Myxomycetes++	-	-	-
Pithomyces++	-	-	-
Rust	-	-	-
Scopulariopsis/Microascus	-	-	-
Stachybotrys/Memnoniella	-	-	-
Cercospora++	-	-	-
Nigrospora	-	-	-
Oidium++	-	-	-
Pestalotia++	-	-	-
Pyricularia	-	-	-
Total Fungi	-	None Detect	-
Hyphal Fragment	-	-	-
Insect Fragment	-	-	-
Pollen	-	-	-
Analyt. Sensitivity 600x	-	44	-
Analyt. Sensitivity 300x	-	13*	-
Skin Fragments (1-4)	-	1	-
Fibrous Particulate (1-4)	-	1	-
Background (1-5)	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

Kimberly Wallace, Laboratory Manager
or other Approved Signatory

No discernable field blank was submitted with this group of samples.

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted. High levels of background particulate can obscure spores and other particulates, leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. **** Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. Skin & Fibrous ratings: 1 (1-25%), 2 (26-50%), 3 (51-75%), 4 (76-100%) of the background particles.

Samples analyzed by EMSL Analytical, Inc. N. Miami Beach, FL AIHA-LAP, LLC-EMLAP Accredited #102813

Initial report from: 10/15/2022 12:51 PM

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com

172205470

Chain of Custody
Laboratory Sample Submittal Form

Phone: (954) 792-4549
 Fax: (954) 792-2221
 Toll Free: (877) 247-8146
 Email: labresults@airquestinc.com
 TAT: 3 Hr. ; 6 Hr. ; 24 Hr. ; Other



6851 SW 45th Street
 Fort Lauderdale, Florida 33314

Sample Date: 10-14-22
 Project Number: 19751-Skyline Elem. School
 Site Address: 620 SW 19th St.
 Cape Coral, FL 33991
 Collected By: GEORGE RAMONDO

Bulk Sample Type	
Code	Description
TL	Tape Lift Sample for Fungi
SW	Swab Sample for Fungi
WP	Wipe Sample for Fungi
BF	Bulk Sample for Fungi
BB	Bulk Sample for E. Coli/Total Coliform
Other	
Other	
Other	

Air Sample Type	
Code	Description
AOC	Air/Cell Sample for Fungi & Particulate
AS	N6 Sample for Viable Fungi
ASB	N6 Sample for Bacteria
Other	

Item	Code	Sample Number	Description	Location	Volume/Quantity/Area	Comments
1	AOL	SES-01	Baseline Comparison	OUTDOORS - West	75 L.T.	
2	↓	SES-02	" "	OUTDOORS - North	↓	
3	↓	SES-03	Breathing Zone	BLDG. 4 - Media Center	↓	"OPEN AREA"
4	↓	SES-04	↓	BLDG. 4 - Media Center	↓	"Rear Corridor"
5	↓	SES-05	↓	CAFETERIA	↓	
6	↓	SES-06	↓	Kitchen	↓	
7	↓	SES-07	↓	06-032 ART	↓	
8	↓	SES-08	↓	06-034-Resource	↓	
9	↓	SES-09	↓	05-048-Classroom	↓	
10	↓	SES-10	↓	05-038-Classroom	↓	

Relinquished by: Wayne Sanchez Initial WS Tracking # _____
 Received by: Meg Planel Fedex: Hand Courtered
 Relinquished by: _____ Date & Time: 10-14-22 @ 6:20
 Received by: _____ Date & Time: 10-15-22 @ 8 AM
 Relinquished by: _____ Date & Time: _____
 Received by: _____ Date & Time: _____

Chain of Custody
Laboratory Sample Submittal Form

Sample Date: 10-14-22
 Project Number: 19751-Skyline Elem. School
 Site Address: 620 SW 7th St
Cape Coral, FL 33991
 Collected By: GEORGE RAMONDO

Phone: (954) 792-4549
 Fax: (954) 792-2221
 Toll Free: (877) 247-8146
 Email: labresults@airquestinc.com
 TAT: 3 Hr. ; 6 Hr. ; 24 Hr. ; Other _____



6851 SW 45th Street
 Fort Lauderdale, Florida 33314

Bulk Sample Type	
Code	Description
TL	Tape Lift Sample for Fungi
SW	Swab Sample for Fungi
WP	Wipe Sample for Fungi
BF	Bulk Sample for Fungi
BB	Bulk Sample for E. Coli/Total Coliform
Other	
Other	
Other	

Air Sample Type	
Code	Description
AOC	Air/Cell Sample for Fungi & Particulate
AS	N6 Sample for Viable Fungi
ASB	N6 Sample for Bacteria
Other	

Item	Code	Sample Number	Description	Location	Volume/Quantity /Area	Comments
1	AUX	SES-11	Breathing Zone	05-043 Classroom	75 LT.	
2	"	SES-12	↓	03-054 Classroom	↓	
3	"	SES-13	↓	03-055 Classroom	↓	
4	"	SES-14	↓	03-056-Teachers Lounge	↓	
5	"	SES-15	↓	07-009 Classroom	↓	
6	"	SES-16	↓	07-014 Classroom	↓	
7	"	SES-17	↓	07-005 Classroom	↓	
8	"	SES-18	↓	07-010 Classroom	↓	
9	"	SES-19	↓	99-2187-Portable	↓	
10		SES-20	Baseline Comp.	OUT doors - WEST		

Relinquished by: George Ramondo Date & Time: 10-14-22 @ 16:30 Initial _____ Tracking # _____
 Received by: Mig Angel Date & Time: 10-15-22 @ 8:00am FedEx: _____
 Relinquished by: _____ Date & Time: _____ Hand Courtered
 Received by: _____ Date & Time: _____

Chain of Custody
Laboratory Sample Submittal Form



6851 SW 45th Street
Fort Lauderdale, Florida 33314

Phone: (954) 792-4549
Fax: (954) 792-2221
Toll Free: (877) 247-8146
Email: labresults@airquestinc.com
TAT: 3 Hr.; 6 Hr.; 24 Hr.; Other

Sample Date: 10-14-22
Project Number: 19751-Skyline Elem. School
Site Address: 620 SW 19th St
Cape Coral, FL 33991
Collected By: GEORGE RAIMONDO

Bulk Sample Type	
Code	Description
TL	Tape Lift Sample for Fungi
SW	Swab Sample for Fungi
WP	Wipe Sample for Fungi
BF	Bulk Sample for Fungi
BB	Bulk Sample for E. Coli/Total Coliform
Other	
Other	
Other	

Air Sample Type	
Code	Description
AOC	Air/Cell Sample for Fungi & Particulate
AS	N6 Sample for Viable Fungi
ASB	N6 Sample for Bacteria
Other	

Item	Code	Sample Number	Description	Location	Volume/Quantity /Area	Comments
1	AOC	SES-21	Breathing Zone	14-211 Resource Planning	75.6T.	
2	↓	SES-22	"	14-207 Class Room	↓	
3	↓	SES-23	"	14-202 Class Room	↓	
4	↓	SES-24	"	14-009 Class Room	↓	
5	↓	SES-25	"	14-006 Class Room	↓	
6		SES-26	"	13-209 Class Room	↓	
7		SES-27	"	13-208 Class Room	↓	
8		SES-28	"	13-204 Class Room	↓	
9		SES-29	"	13-009 Class Room	↓	
10		SES-30	"	13-003 Class Room	↓	

Relinquished by: George Raimondo Date & Time: 10-14-22 @ 16:30 Initial GR Tracking # _____
 Received by: Miguel Raimondo Date & Time: 10-15-22 8 AM Fedex: _____
 Relinquished by: _____ Date & Time: _____ Hand Courtered
 Received by: _____ Date & Time: _____

Chain of Custody
Laboratory Sample Submittal Form

Sample Date: 10-14-22
 Project Number: 16751 - Skyline Elem. School
 Site Address: 620 SW 19th St
Sage Coral, Fl. 33991
 Collected By: George Ramonudo

Phone: (954) 792-4549
 Fax: (954) 792-2221
 Toll Free: (877) 247-8146
 Email: labresults@airquestinc.com
 TAT: 3 Hr. ; 6 Hr. ; 24 Hr. ; Other _____



6851 SW 45th Street
 Fort Lauderdale, Florida 33314

Bulk Sample Type	
Code	Description
TL	Tape Lift Sample for Fungi
SW	Swab Sample for Fungi
WP	Wipe Sample for Fungi
BF	Bulk Sample for Fungi
BB	Bulk Sample for E. Coli/Total Coliform
Other	
Other	
Other	

Air Sample Type	
Code	Description
AOC	Air/Cell Sample for Fungi & Particulate
AS	N6 Sample for Viable Fungi
ASB	N6 Sample for Bacteria
Other	

Item	Code	Sample Number	Description	Location	Volume/Quantity /Area	Comments
1	AOL	SES-31	Breathing Zone	13-006 Classroom	75. Lt.	
2		SES-32	↓	08-016 Classroom	↓	
3		SES-33	↓	08-020 Classroom	↓	(08-020)
4		SES-34	N	09-023 Classroom	↓	
5		SES-35	N	09-027 Classroom	↓	
6		SES-36	N	065 - Main Office	↓	(FRONT DESK)
7		SES-37	N	065 - Main Office	↓	(BREAK AREA)
8						
9						
10						

Relinquished by: George Ramonudo Initial GR Tracking # _____

Received by: Meg Hamel Fedex:

Relinquished by: _____ Hand Couriered:

Received by: _____

Date & Time: 10-14-22 @ 16:30
 Date & Time: 10-15-22 8 AM
 Date & Time: _____
 Date & Time: _____

Roof damage
Reported Minimal Water
Intrusion

Daily Summary

School: Skyline Elementary School (SE)
Date: 10/11/22

Room / Area:

PRV

NOTES

Room / Area	Passed	Failed	NOTES
<u>Office</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>AGI cleanup completed</u>
1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<u>2</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<u>3</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<u>4</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<u>5</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<u>6</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<u>7</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<u>8</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<u>9</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
10	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
10	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
10	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<u>13</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<u>14</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>Ceiling tile cleanup completed</u>
<u>PE office</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
<u>Portable</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<u>Wet drywall abv window</u>
	<input type="checkbox"/>	<input type="checkbox"/>	
	<input type="checkbox"/>	<input type="checkbox"/>	
	<input type="checkbox"/>	<input type="checkbox"/>	

SCHOOL: SE
Room / Area: 1-Office

Date: 10/11/22

Temp.	rH%	Dew Point
78	43	54

P R V NOTES

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- North Wall Clean Stained VMG
- East Wall Clean Stained VMG
- South Wall Clean Stained VMG
- West Wall Clean Stained VMG

Flooring:

- Clean
- Dirty
- VMG
- Wet
- Dry

Air Sampling:

- YES
- NO

- A O C
- Date: ___/___/___

NOTES:

Date: 10/14/22

SCHOOL: SE
Room / Area: PE Pavillion
Office

Temp.	rH%	Dew Point

P R V NOTES

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- North Wall Clean Stained VMG
- East Wall Clean Stained VMG
- South Wall Clean Stained VMG
- West Wall Clean Stained VMG

Flooring:

- Clean
- Dirty
- VMG
- Wet
- Dry

Air Sampling:

- YES
- NO

A O C

Date: ___/___/___

NOTES:

SCHOOL: SE

Date: 10/14/22

Room / Area: 2B-Cafeteria / 60
Music

Temp.	rH%	Dew Point
84	57	67

P R V NOTES

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- North Wall Clean Stained VMG
- East Wall Clean Stained VMG
- South Wall Clean Stained VMG
- West Wall Clean Stained VMG

Flooring:

- Clean Wet
- Dirty Dry
- VMG

Air Sampling:

- YES NO

A O C

Date: / /

NOTES:

60 - 4 ACT stained, dry

Date: 10/14/22

SCHOOL: SE
Room / Area: 31C

Temp.	rH%	Dew Point
72	51	58

P R V NOTES

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- | | | | |
|------------|--------------------------------|----------------------------------|------------------------------|
| North Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| East Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| South Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| West Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |

Flooring:

- | | |
|---|------------------------------|
| <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Wet |
| <input type="checkbox"/> Dirty | <input type="checkbox"/> Dry |
| <input type="checkbox"/> VMG | |

Air Sampling:

- YES NO
- AOC
- Date: __/__/__

NOTES:

03-056: 1 ACT stained, dry

SCHOOL:

Skyline Elementary School

Date: 10/14/22 (SE)

Room / Area:

Media

Bldg 4

Temp.	rH%	Dew Point
88	47	65

PRV NOTES

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- | | | | |
|------------|--------------------------------|----------------------------------|------------------------------|
| North Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| East Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| South Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| West Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |

Flooring:

- Clean
- Dirty
- VMG
- Wet
- Dry

Air Sampling:

YES

NO

AOC

Date: ___/___/___

NOTES:

04-058F - Active, slow/minor condensation on chilled water pipe. less than 1 SF wet carpet.

SCHOOL:

SE

Date: 10/14/22

Room / Area:

S/E

Temp.	rH%	Dew Point
82	49	56

P R V NOTES

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- | | | | |
|------------|---|----------------------------------|------------------------------|
| North Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| East Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| South Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| West Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |

Flooring:

- | | |
|---|------------------------------|
| <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Wet |
| <input type="checkbox"/> Dirty | <input type="checkbox"/> Dry |
| <input type="checkbox"/> VMG | |

Air Sampling:

- YES NO

A O C

Date: ___/___/___

NOTES:

SCHOOL:

S E

Date: 10/14/22

Room / Area:

6

Temp.	rH%	Dew Point
79	42	55

PRV NOTES

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- North Wall Clean Stained VMG
- East Wall Clean Stained VMG
- South Wall Clean Stained VMG
- West Wall Clean Stained VMG

Flooring:

- Clean Wet
- Dirty Dry
- VMG

Air Sampling:

- YES NO

A O C

Date: __/__/__

NOTES:

7

Date: 10/14/22

SCHOOL: SE

Room / Area: 7

Temp.	rH%	Dew Point
82	41	54

P R V NOTES

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- | | | | |
|------------|---|---|------------------------------|
| North Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| East Wall | <input type="checkbox"/> Clean | <input checked="" type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| South Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| West Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |

Flooring:

- Clean
- Dirty
- VMG
- Wet
- Dry

Air Sampling:

- YES
- NO

A O C

Date: / /

NOTES:

7-001: stained concrete ^{wall} from plumbing leak

7-009: I stained ACT, dry

SCHOOL: SE
Room / Area: 8

Date: 10/14/22

Temp.	rH%	Dew Point
84	43	59

P R V NOTES

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- North Wall Clean Stained VMG
- East Wall Clean Stained VMG
- South Wall Clean Stained VMG
- West Wall Clean Stained VMG

Flooring:

- Clean Dirty VMG
- Wet Dry

Air Sampling:

- YES NO

- A O C
- Date: ___/___/___

NOTES:

Date: 10/14/22

SCHOOL: SE
Room / Area: 9

Temp.	rH%	Dew Point
79	49	58

PRV NOTES

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- North Wall Clean Stained VMG
- East Wall Clean Stained VMG
- South Wall Clean Stained VMG
- West Wall Clean Stained VMG

Flooring:

- Clean Wet
- Dirty Dry
- VMG

Air Sampling:

- YES NO

A O C

Date: ___/___/___

NOTES:

SCHOOL: SE

Date: 10/14/22

Room / Area: 13

Temp.	rH%	Dew Point
81	45	56

P R V NOTES

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- | | | | |
|------------|---|----------------------------------|------------------------------|
| North Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| East Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| South Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| West Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |

Flooring:

- Clean
- Dirty
- VMG
- Wet
- Dry

Air Sampling:

- YES
- NO
- A O C
- Date: ___/___/___

NOTES:

Date: 10/14/22

SCHOOL: SE
Room / Area: 14

Temp.	rH%	Dew Point
82	47	66

PRV NOTES

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- | | | | |
|------------|--------------------------------|----------------------------------|------------------------------|
| North Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| East Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| South Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| West Wall | <input type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |

Flooring:

- Clean
- Dirty
- VMG
- Wet
- Dry

Air Sampling:

- YES
- NO

AOC

Date: ___/___/___

NOTES:

14-019: 2 ACT, stained, dry
 : 1 ACT, wet
 outside 14-202: 4 SF stained dry wall, dry
 inside 14-202: wet spot on carpet from roof
 leak above

SCHOOL:

SE

Date: 10/12/22

Room / Area:

Portables

Temp.	rH%	Dew Point
84	43	59

P R V NOTES

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- | | | | |
|------------|---|---|------------------------------|
| North Wall | <input type="checkbox"/> Clean | <input checked="" type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| East Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| South Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| West Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |

Flooring:

- | | |
|---|------------------------------|
| <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Wet |
| <input type="checkbox"/> Dirty | <input type="checkbox"/> Dry |
| <input type="checkbox"/> VMG | |

Air Sampling:

- YES NO

AOC

Date: ___/___/___

NOTES:

Wet drywall header above window

Date: 10/14/22

SCHOOL: SE

Room / Area: Portables

Temp.	rH%	Dew Point
84	43	59

P R V NOTES

Ambiente Air:

- Normal
- Clean / Fresh
- Musty / Odor

Ceiling Tiles:

- Clean
- Remaining Stained
- Remaining VMG

Walls:

- | | | | |
|------------|---|---|------------------------------|
| North Wall | <input type="checkbox"/> Clean | <input checked="" type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| East Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| South Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |
| West Wall | <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Stained | <input type="checkbox"/> VMG |

Flooring:

- | | |
|---|------------------------------|
| <input checked="" type="checkbox"/> Clean | <input type="checkbox"/> Wet |
| <input type="checkbox"/> Dirty | <input type="checkbox"/> Dry |
| <input type="checkbox"/> VMG | |

Air Sampling:

- YES NO

A O C

Date: ___/___/___

NOTES: Wet drywall header above window

Skyline Elementary School

2022-2023

